

Asbestos – Restricted Areas



ASBESTOS RESTRICTED AREA LIST

Procedure for access:

Notify Environmental Health and Safety (206.543.7262) of the need to enter the area. Identify the activity to occur. You will be advised of the cautionary measures required, which may include air monitoring, preparation of the area, protective clothing, and special precautions during work.

UW Facilities personnel must call the Regulated Materials Office (206.685.3357) for access.

Please Note: If a material is not on this list, do not assume it does not contain asbestos. Contact your supervisor for sampling information.

Building	Location	Description	Comment
Aerospace Engineering Research Building	Ceiling tiles for most perimeter offices on the south side.	ACM ceiling tiles in rooms on the south side (floors 1-4) and west side of floor 1.	Excludes: Ceiling tiles in eastside addition and rooms 228 and 428 do not contain asbestos.
Anderson Hall	Perimeter crawlspace	Damaged asbestos pipe insulation in perimeter crawlspace/tunnels	Crawlspace accessed through mechanical room, room 22 floor, and exterior louver on east side of building.
Atmospheric Sciences Geophysics Building	Ceiling tiles and above	Original ceiling tiles sampled and found to contain asbestos.	On floors 1-5, and 7. Excludes: Floor 6 was remodeled, and ceiling tiles were replaced.
	Pipe chase hatch access	Hard block pipe insulation on straight runs, TSI.	
Bagley Hall	Pipe chases	Deteriorated asbestos insulation in pipe chases.	Pipe chases that are not restricted are marked with "nonrestricted" signs.
	Dirt crawl space	Dirt crawl space with some soil samples showing presence of asbestos.	
Edmundson Pavilion Pool	Pool dirt crawl space	Asbestos insulation/debris in dirt.	Crawl space entered from pool mechanical room.

ASBESTOS RESTRICTED AREA LIST

Building	Location	Description	Comment
Haggett Hall Garage	Ceiling space above parking garage N-9	Asbestos pipe insulation debris and damaged hard pipe insulation.	Currently being demolished.
Henderson Hall (APL)	Northwest section of roof	Damaged asbestos and lead-containing paint	
Hutchinson Hall	Dirt crawl spaces	Dirt crawl space with asbestos debris contamination.	
Lewis Hall	Crawl space off mechanical room	Dirt crawl space with asbestos debris contaminating space.	The mechanical room is outside SE entrance.
Magnuson Health Sciences Center	A-Wing – A515 and A420A	Asbestos-containing debris in A420A.	A420A is accessed through A515.
	A wing - attic space above Hogness Auditorium ceiling (4th floor)	Deteriorated asbestos tape and mud on exterior insulation of abandoned ductwork.	
	A-Wing pipe chases	Damaged pipe insulation throughout	
Magnuson Health Sciences Center	B wing - pipe chases	Damaged pipe insulation throughout	
Magnuson Health Sciences Center	BB Wing - areas above suspended ceilings for floors 9-16	Structural steel with spray-on insulation. Debris may be on top surface of ceiling tiles.	All areas where spray-on insulation is present, and which have suspended ceilings.
			<p>Excludes: Rooms 1344 and 1338, and part of the adjacent corridor, which were abated, and room 919B where the spray-on is non-ACM.</p> <p>CAUTION: Even after the tiles have been cleaned, work done in the ceiling space may cause more delamination. Precautions must be taken to avoid such delamination.</p>
Magnuson Health Sciences Center	BB wing - pipe chases floors 1-16	Asbestos-containing spray-on insulation inside pipe chases	

ASBESTOS RESTRICTED AREA LIST

Building	Location	Description	Comment
Magnuson Health Sciences Center	C wing – pipe riser section along north wall of interstitial space on floors 5 & 6	Damaged pipe insulation throughout	
Magnuson Health Sciences Center	RR wing - pipe chases	Damaged pipe insulation throughout	Access restricted until debris is cleaned and insulation is encapsulated and/or abated.
Magnuson Health Sciences Center	T wing - areas above suspended ceilings	Structural steel with spray-on insulation. Debris may be on top surface of ceiling tiles.	All areas where spray-on insulation is present, and which have suspended ceilings. Excludes: Corridor T-102J CAUTION: Even after the tiles have been cleaned, work done in the ceiling space may cause more delamination. Precautions must be taken to avoid such delamination.
Magnuson Health Sciences Center	T-Wing return air shafts	Spray-on fireproofing on structural members and overspray throughout.	
McMahon Hall	Pipe Chases in North and South Towers	Damaged asbestos pipe insulation and debris in pipe chases.	
More Hall	Third floor ceiling spaces north of main corridor and ceiling spaces above main corridor.	Spray-on material above suspended and hard ceilings.	CAUTION: Even after the ceiling space has been cleaned, work done in the space may cause more delamination. Precautions must be taken to avoid such delamination.
Old Oceanography Building	Room 121, floor pipe chase	Damaged and deteriorated asbestos pipe insulation in floor chase.	Access hatch located on wall in room 121.
Old Fisheries Building (Portage Bay Building)	Pipe chases in the west wing of the building, floors 1 & 2.	Damaged asbestos pipe insulation & insulation debris in several areas.	
Plant Operations Annex 4	Dirt Crawlspace Areas	Asbestos-containing debris in dirt crawlspace.	

ASBESTOS RESTRICTED AREA LIST

Building	Location	Description	Comment
Schmitz Hall	Areas above suspended ceilings	Spray-on material on concrete. Debris may be on top surface of ceiling tile.	All areas where spray-on material is present, and which have suspended ceilings. Excludes: Asbestos spray-on has been removed from the loading dock, storage areas, and mechanical room. These areas were reinsulated with non-ACM insulation with a blue tint. CAUTION: Even after the tiles have been cleaned, work done in the ceiling space may cause more delamination. Precautions must be taken to avoid such delamination.
	Smith Hall	Crawlspace in room 120-C	Damaged pipe insulation present throughout crawlspace.
	Areas above suspended ceiling tiles.	Damaged fireproofing on select areas above ceiling tiles.	
Suzzallo Library	Crawl space under men's restroom	Deteriorated insulation in crawl space.	Access through G050F tunnel entrance (need ladder to access).
Utility Tunnels	West of MC-7 to the Central Plaza Garage.	Deteriorated asbestos insulation on pipework and floor.	
	Mid-Campus Tunnel	Deteriorated asbestos insulation and surface contamination	Accessed through Compressor Building.
UW Tower – C Building	C-Building 4 th Floor Ceiling Cavity	Deteriorated spray applied fireproofing in ceiling cavity on 4 th floor	