

Fume Hoods Status

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
3/22/2023	3018 WESTERN AVENUE	223	Regional Primate Research Center	1833	Active	Passed		92	16	40
3/22/2023	3018 WESTERN AVENUE	21	Regional Primate Research Center	1631	Active	Passed		120	24	40
3/22/2023	3018 WESTERN AVENUE	43	Regional Primate Research Center	1632	Active	Passed		119	24	64
5/31/2024	AEROSPACE/ENGR RESEARCH	318	Bioengineering	895	Active	Passed		105	24	60
5/31/2024	AEROSPACE/ENGR RESEARCH	318	Bioengineering	1232	Active	Passed		140	18	60
5/31/2024	AEROSPACE/ENGR RESEARCH	323	Bioengineering	154	Active	Passed		78	18	36
5/31/2024	AEROSPACE/ENGR RESEARCH	323	Bioengineering	155	Active	Passed		84	18	36
5/31/2024	AEROSPACE/ENGR RESEARCH	323	Bioengineering	1019	Active	Passed		123	18	60
5/31/2024	AEROSPACE/ENGR RESEARCH	317	Bioengineering	1602	Active	Passed		142	18	64
4/17/2024	ARCF - ANIMAL RSCH CARE FAC	B-160	Comparative Medicine	2548	Active	Passed		80	18	48
4/17/2024	ARCF - ANIMAL RSCH CARE FAC	B-238	Comparative Medicine	2549	Active	Passed		80	18	58
10/30/2024	ART BUILDING	201-B	School of Art	267	Active	Passed		120	24	48
10/30/2024	ART BUILDING	201-B	School of Art	265	Active	Passed		121	24	48
10/30/2024	ART BUILDING	201-B	School of Art	266	Active	Passed		134	24	48
2/8/2023	ATMOS SCI/GEOPHYSICS	155	Earth , Space and Science	568	Inactive	Passed		0	0	38
9/24/2024	ATMOS SCI/GEOPHYSICS	056B	Quaternary Research Center	758	Active	Passed		99	18	50
9/24/2024	ATMOS SCI/GEOPHYSICS	034	Quaternary Research Center	569	Active	Passed		111	21	50
9/24/2024	ATMOS SCI/GEOPHYSICS	044	Quaternary Research Center	570	Active	Passed		96	32	38
9/24/2024	ATMOS SCI/GEOPHYSICS	044A	Quaternary Research Center	571	Active	Passed		86	33	38

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
9/24/2024	ATMOS SCI/GEOPHYSICS	056	Quaternary Research Center	756	Active	Passed		91	21	50
9/24/2024	ATMOS SCI/GEOPHYSICS	325	Atmospheric Sciences	1574	Active	Passed		100	22	40
9/24/2024	ATMOS SCI/GEOPHYSICS	510	Quaternary Research Center	150	Active	Passed		114	18	50
9/24/2024	ATMOS SCI/GEOPHYSICS	056	Quaternary Research Center	757	Active	Passed		113	20	50
2/21/2023	BAGLEY HALL	444	Chemistry	107	Active	Passed		107	18	
4/19/2023	BAGLEY HALL	473	Chemistry	94	Active	Passed		98	18	44
4/28/2023	BAGLEY HALL	442-A	Chemistry	1834	Active	Passed		100	18	60
6/16/2023	BAGLEY HALL	392	Chemistry	146	Active	Passed		152	18	
10/16/2023	BAGLEY HALL	235	Chemistry	2316	Active	Passed		105	18	62
10/16/2023	BAGLEY HALL	236	Unknown	2529	Active	Passed		104	18	63
10/16/2023	BAGLEY HALL	235	Chemistry	2317	Active	Passed		96	18	62
10/16/2023	BAGLEY HALL	270	Chemistry	412	Active	Passed		93	18	40
10/16/2023	BAGLEY HALL	290D	Chemistry	2072	Active	Passed		99	18	38
10/16/2023	BAGLEY HALL	236	Unknown	2530	Active	Passed		114	18	63
10/16/2023	BAGLEY HALL	290C	Chemistry	2071	Active	Passed		74	18	86
10/16/2023	BAGLEY HALL	290C	Chemistry	2070	Active	Failed		123	18	86
10/16/2023	BAGLEY HALL	291-c	Chemistry	2233	Active	Passed		68	18	63
10/16/2023	BAGLEY HALL	233	Chemistry	2318	Active	Passed		105	18	62
10/16/2023	BAGLEY HALL	234	Unknown	2531	Active	Passed		121	18	63
10/16/2023	BAGLEY HALL	234	Unknown	2532	Active	Passed		108	18	63
10/16/2023	BAGLEY HALL	233	Chemistry	2319	Active	Passed		102	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/17/2023	BAGLEY HALL	458A	Bioengineering	1615	Active	Failed		183	18	60
10/17/2023	BAGLEY HALL	442	Bioengineering	1613	Active	Failed		162	18	50
10/17/2023	BAGLEY HALL	442	Bioengineering	1611	Active	Passed		145	18	50
10/17/2023	BAGLEY HALL	467	Bioengineering	1614	Active	Failed		116	18	60
10/17/2023	BAGLEY HALL	453	Chemistry	2062	Active	Passed		80	18	62
10/17/2023	BAGLEY HALL	442B	Bioengineering	1607	Active	Failed		173	18	50
10/17/2023	BAGLEY HALL	459	Chemistry	2059	Active	Passed		97	18	62
10/17/2023	BAGLEY HALL	454A	Chemistry	2535	Active	Passed		82	18	62
10/17/2023	BAGLEY HALL	459	Chemistry	2060	Active	Passed		68	18	62
10/17/2023	BAGLEY HALL	453	Chemistry	2061	Active	Passed		69	18	62
10/18/2023	BAGLEY HALL	442	Chemistry	2057	Active	Passed		84	18	86
10/18/2023	BAGLEY HALL	442	Chemistry	2058	Active	Passed		97	18	76
10/18/2023	BAGLEY HALL	442	Bioengineering	1612	Active	Failed		151	18	50
10/18/2023	BAGLEY HALL	411	Chemistry	2064	Active	Passed		76	18	72
10/18/2023	BAGLEY HALL	442	Bioengineering	1608	Active	Passed		118	18	50
10/18/2023	BAGLEY HALL	411	Chemistry	2066	Active	Passed		66	18	72
10/18/2023	BAGLEY HALL	442	Bioengineering	1610	Active	Failed		166	18	50
10/18/2023	BAGLEY HALL	411	Chemistry	1803	Active	Passed		96	18	72
10/18/2023	BAGLEY HALL	411	Chemistry	2065	Active	Passed		59	18	72
10/18/2023	BAGLEY HALL	411	Chemistry	2068	Active	Passed		77	18	72
10/18/2023	BAGLEY HALL	411	Chemistry	2063	Active	Passed		74	18	72

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/18/2023	BAGLEY HALL	411	Chemistry	2067	Active	Passed		66	18	62
10/18/2023	BAGLEY HALL	442	Chemistry	2056	Active	Passed		77	18	86
10/19/2023	BAGLEY HALL	397C	Chemistry	2087	Active	Passed		86	18	72
10/19/2023	BAGLEY HALL	442	Bioengineering	1609	Active	Failed		204	2422	22
10/19/2023	BAGLEY HALL	393	Chemistry	2083	Active	Passed		75	18	72
10/19/2023	BAGLEY HALL	398	Chemistry	2089	Active	Passed		82	18	72
10/19/2023	BAGLEY HALL	398	Chemistry	2088	Active	Passed		111	18	72
10/19/2023	BAGLEY HALL	397C	Chemistry	2086	Active	Passed		79	18	72
10/19/2023	BAGLEY HALL	397C	Chemistry	2085	Active	Passed		76	18	72
10/19/2023	BAGLEY HALL	392	Chemistry	2092	Active	Passed		78	18	72
10/19/2023	BAGLEY HALL	402	Chemistry	1802	Active	Passed		146	18	80
10/19/2023	BAGLEY HALL	398	Chemistry	2090	Active	Passed		79	18	72
10/19/2023	BAGLEY HALL	397C	Chemistry	2084	Active	Passed		114	18	72
10/19/2023	BAGLEY HALL	398	Chemistry	2091	Active	Passed		85	18	72
10/20/2023	BAGLEY HALL	389	Chemistry	2082	Active	Passed		70	18	72
10/20/2023	BAGLEY HALL	389	Chemistry	2081	Active	Passed		85	18	72
10/20/2023	BAGLEY HALL	389	Chemistry	2073	Active	Passed		77	18	72
10/20/2023	BAGLEY HALL	389	Chemistry	2080	Active	Passed		91	18	72
10/20/2023	BAGLEY HALL	389	Chemistry	2076	Active	Passed		77	18	72
10/20/2023	BAGLEY HALL	389	Chemistry	2079	Active	Passed		92	18	72
10/20/2023	BAGLEY HALL	389	Chemistry	2075	Active	Passed		88	18	72

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/20/2023	BAGLEY HALL	389	Chemistry	2077	Active	Passed		88	18	72
10/20/2023	BAGLEY HALL	389	Chemistry	2074	Active	Passed		89	18	72
10/20/2023	BAGLEY HALL	389	Chemistry	2078	Active	Passed		86	18	72
10/23/2023	BAGLEY HALL	339	Chemistry	354	Active	Passed		97	26	40
10/23/2023	BAGLEY HALL	326	Chemistry	1742	Active	Passed		102	26	50
10/23/2023	BAGLEY HALL	314	Chemistry	133	Active	Passed		119	18	50
10/23/2023	BAGLEY HALL	306	Chemistry	129	Active	Passed		93	21	50
10/23/2023	BAGLEY HALL	333	Chemistry	1569	Active	Failed		163	18	52
10/23/2023	BAGLEY HALL	333	Chemistry	1567	Active	Failed		177	18	52
10/23/2023	BAGLEY HALL	320	Chemistry	2546	Active	Passed		78	18	54
10/23/2023	BAGLEY HALL	366	Chemistry	1739	Active	Passed		125	18	52
10/23/2023	BAGLEY HALL	333	Chemistry	1568	Active	Failed		170	18	52
10/23/2023	BAGLEY HALL	365	Chemistry	1741	Active	Passed		104	26	60
10/23/2023	BAGLEY HALL	365	Chemistry	1740	Active	Passed		113	26	60
10/24/2023	BAGLEY HALL	336A	Chemistry	1808	Active	Failed		129	23	64
10/24/2023	BAGLEY HALL	362A	Chemistry	829	Active	Passed		99	29	60
10/24/2023	BAGLEY HALL	362	Chemistry	1818	Active	Passed		97	28	40
10/24/2023	BAGLEY HALL	336A	Chemistry	1813	Active	Failed		144	21	64
10/24/2023	BAGLEY HALL	208	Chemistry	452	Active	Passed		122	28	50
10/24/2023	BAGLEY HALL	336A	Chemistry	1812	Active	Passed		90	26	64
10/24/2023	BAGLEY HALL	336A	Chemistry	1809	Active	Failed		138	26	64

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/24/2023	BAGLEY HALL	336B	Chemistry	1806	Active	Passed		113	28	64
10/24/2023	BAGLEY HALL	336B	Chemistry	1807	Active	Passed		128	25	64
10/24/2023	BAGLEY HALL	336A	Chemistry	1810	Active	Failed		95	26	64
10/25/2023	BAGLEY HALL	293	Chemistry	445	Active	Passed		126	17	45
10/25/2023	BAGLEY HALL	293	Chemistry	447	Active	Passed		124	17	45
10/25/2023	BAGLEY HALL	293	Chemistry	440	Active	Passed		99	17	45
10/25/2023	BAGLEY HALL	293	Chemistry	448	Active	Passed		111	17	45
10/25/2023	BAGLEY HALL	293	Chemistry	443	Active	Passed		120	15	45
10/25/2023	BAGLEY HALL	220	Chemistry	2457	Active	Passed		71	18	88
10/25/2023	BAGLEY HALL	293	Chemistry	444	Inactive	Failed		31	25	45
10/25/2023	BAGLEY HALL	293	Chemistry	442	Active	Passed		133	15	45
10/25/2023	BAGLEY HALL	293	Chemistry	436	Active	Passed		119	24	48
10/25/2023	BAGLEY HALL	293	Chemistry	437	Active	Passed		103	24	48
10/25/2023	BAGLEY HALL	293	Chemistry	441	Active	Passed		108	17	45
10/25/2023	BAGLEY HALL	220	Chemistry	2458	Active	Passed		95	18	88
10/26/2023	BAGLEY HALL	192B	Chemistry	1055	Active	Passed		129	18	50
10/26/2023	BAGLEY HALL	192B	Chemistry	1054	Active	Passed		103	18	50
10/26/2023	BAGLEY HALL	192F	Chemistry	998	Active	Failed		74	18	50
10/26/2023	BAGLEY HALL	192A	Chemistry	1051	Active	Passed		113	18	50
10/26/2023	BAGLEY HALL	192F	Chemistry	999	Active	Passed		96	18	50
10/26/2023	BAGLEY HALL	192B	Chemistry	1053	Active	Passed		99	18	50

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/26/2023	BAGLEY HALL	192A	Chemistry	1050	Active	Passed		81	18	50
10/26/2023	BAGLEY HALL	192C	Chemistry	1007	Active	Passed		100	18	50
10/26/2023	BAGLEY HALL	192C	Chemistry	1006	Active	Passed		111	18	50
10/26/2023	BAGLEY HALL	192B	Chemistry	1056	Active	Passed		114	18	50
10/26/2023	BAGLEY HALL	192A	Chemistry	1049	Active	Passed		86	18	50
10/26/2023	BAGLEY HALL	192E	Chemistry	1001	Active	Passed		102	18	50
10/26/2023	BAGLEY HALL	192A	Chemistry	1052	Active	Passed		112	18	50
10/26/2023	BAGLEY HALL	192C	Chemistry	1004	Active	Passed		113	18	50
10/26/2023	BAGLEY HALL	192D	Chemistry	1003	Active	Passed		108	18	50
10/26/2023	BAGLEY HALL	192D	Chemistry	1002	Active	Passed		119	18	50
10/26/2023	BAGLEY HALL	192C	Chemistry	1005	Active	Passed		115	18	50
10/27/2023	BAGLEY HALL	291-b	Chemistry	2232	Active	Passed		68	18	60
10/27/2023	BAGLEY HALL	291-b	Chemistry	2231	Active	Passed		77	18	60
10/27/2023	BAGLEY HALL	291-a	Chemistry	2230	Active	Failed		78	18	60
10/27/2023	BAGLEY HALL	205	Chemistry	450	Active	Passed		98	21	60
10/27/2023	BAGLEY HALL	293	Chemistry	438	Active	Passed		98	24	60
10/27/2023	BAGLEY HALL	293	Chemistry	439	Active	Passed		111	24	60
10/27/2023	BAGLEY HALL	291-a	Chemistry	2229	Active	Passed		62	18	60
11/1/2023	BAGLEY HALL	191	Chemistry	1895	Active	Passed		92	18	86
11/1/2023	BAGLEY HALL	191	Chemistry	1900	Active	Passed		76	18	86
11/1/2023	BAGLEY HALL	133	Chemistry	2649	Active	Passed		100	18	86

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
11/1/2023	BAGLEY HALL	133	Chemistry	2651	Active	Passed		82	18	86
11/1/2023	BAGLEY HALL	133	Chemistry	2650	Active	Passed		87	18	86
11/1/2023	BAGLEY HALL	191	Chemistry	1892	Active	Passed		76	18	86
11/1/2023	BAGLEY HALL	191	Chemistry	1894	Active	Passed		86	18	86
11/1/2023	BAGLEY HALL	191	Chemistry	1896	Active	Passed		84	18	86
11/1/2023	BAGLEY HALL	191	Chemistry	1897	Active	Passed		90	18	86
11/1/2023	BAGLEY HALL	191	Chemistry	1898	Active	Passed		94	18	86
11/1/2023	BAGLEY HALL	133D	Chemistry	334	Active	Passed		119	18	48
11/1/2023	BAGLEY HALL	191	Chemistry	1901	Active	Failed		106	18	86
11/1/2023	BAGLEY HALL	191	Chemistry	1899	Active	Passed		73	18	38
11/1/2023	BAGLEY HALL	191	Chemistry	1893	Active	Passed		87	18	86
11/2/2023	BAGLEY HALL	152-C	Chemistry	1842	Active	Failed		77	18	62
11/2/2023	BAGLEY HALL	171	Chemistry	371	Active	Passed		114	20	88
11/2/2023	BAGLEY HALL	171	Chemistry	369	Active	Passed		143	18	40
11/2/2023	BAGLEY HALL	152-B	Chemistry	1843	Active	Passed		93	18	62
11/2/2023	BAGLEY HALL	162B	Chemistry	1846	Active	Passed		91	18	62
11/2/2023	BAGLEY HALL	171	Chemistry	370	Active	Failed		171	18	40
11/2/2023	BAGLEY HALL	152C	Chemistry	1841	Active	Passed		126	18	62
11/2/2023	BAGLEY HALL	128	Chemistry	329	Active	Passed		139	24	40
11/2/2023	BAGLEY HALL	162B	Chemistry	1845	Active	Passed		93	18	62
11/2/2023	BAGLEY HALL	152-B	Chemistry	1844	Active	Passed		88	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
11/6/2023	BAGLEY HALL	016	Chemistry	1856	Active	Passed		85	18	62
11/6/2023	BAGLEY HALL	073	Chemistry	326	Active	Passed		108	26	38
11/6/2023	BAGLEY HALL	087	Chemistry	337	Active	Passed		83	24	88
11/6/2023	BAGLEY HALL	083	Chemistry	1587	Active	Passed		110	20	36
11/6/2023	BAGLEY HALL	063B	Chemistry	325	Inactive	Passed		0	0	63
11/6/2023	BAGLEY HALL	006	Chemistry	317	Inactive	Failed		4	24	40
11/6/2023	BAGLEY HALL	336A	Chemistry	1811	Active	Passed		112	27	64
11/6/2023	BAGLEY HALL	016	Chemistry	1857	Active	Passed		92	18	62
11/6/2023	BAGLEY HALL	014	Chemistry	318	Active	Passed		107	18	60
11/6/2023	BAGLEY HALL	014	Chemistry	319	Active	Passed		123	20	60
11/6/2023	BAGLEY HALL	005	Chemistry	449	Active	Passed		97	27	60
11/6/2023	BAGLEY HALL	023	Chemistry	323	Active	Passed		91	18	84
11/6/2023	BAGLEY HALL	092	Chemistry	1009	Inactive	Passed		0	0	50
11/6/2023	BAGLEY HALL	083A	Chemistry	365	Active	Passed		96	18	40
11/13/2023	BAGLEY HALL	206	Chemistry	451	Active	Passed		108	23	50
11/13/2023	BAGLEY HALL	020	Chemistry	322	Active	Passed		110	22	48
11/13/2023	BAGLEY HALL	082	Chemistry	1556	Active	Passed		108	16	60
11/13/2023	BAGLEY HALL	082C	Chemistry	1008	Active	Passed		116	22	88
11/13/2023	BAGLEY HALL	030	Chemistry	324	Inactive	Failed		23	29	48
12/5/2023	BAGLEY HALL	333	Chemistry	1566	Active	Failed		164	18	52
4/30/2024	BAGLEY HALL	388	Chemistry	2098	Active	Passed		80	18	72

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
4/30/2024	BAGLEY HALL	388	Chemistry	2094	Active	Passed		86	18	72
4/30/2024	BAGLEY HALL	388	Chemistry	2095	Active	Passed		80	18	72
4/30/2024	BAGLEY HALL	388	Chemistry	2096	Active	Passed		84	18	72
4/30/2024	BAGLEY HALL	388	Chemistry	2093	Active	Passed		74	18	72
4/30/2024	BAGLEY HALL	388	Chemistry	2097	Active	Passed		81	18	72
4/30/2024	BAGLEY HALL	388	Chemistry	2099	Active	Passed		83	18	72
4/30/2024	BAGLEY HALL	388	Chemistry	2100	Active	Passed		85	18	72
4/30/2024	BAGLEY HALL	388	Chemistry	2101	Active	Passed		82	18	72
4/30/2024	BAGLEY HALL	388	Chemistry	2102	Active	Passed		79	18	72
10/21/2024	BAGLEY HALL	326	Chemistry	130	Active	Passed		105	18	48
10/30/2024	BAGLEY HALL	192E	Chemistry	1000	Active	Passed		100	18	50
8/4/2023	BEN HALL INT. RSCH	365	Applied Physics Laboratory	2257	Active	Passed		82	18	38
8/4/2023	BEN HALL INT. RSCH	415	Bioengineering	1995	Active	Passed		125	18	62
8/4/2023	BEN HALL INT. RSCH	308	Applied Physics Laboratory	2103	Active	Passed		71	18	62
8/4/2023	BEN HALL INT. RSCH	309	Applied Physics Laboratory	2104	Active	Passed		67	18	62
8/4/2023	BEN HALL INT. RSCH	310	Applied Physics Laboratory	2105	Active	Passed		77	18	52
8/4/2023	BEN HALL INT. RSCH	311	Applied Physics Laboratory	2106	Active	Passed		78	18	62
8/4/2023	BEN HALL INT. RSCH	361	College of Engineering	2254	Active	Passed		80	18	62
8/4/2023	BEN HALL INT. RSCH	361	College of Engineering	2255	Active	Passed		80	18	62
8/4/2023	BEN HALL INT. RSCH	362	Applied Physics Laboratory	2256	Active	Passed		79	18	38
8/4/2023	BEN HALL INT. RSCH	533	Applied Physics Laboratory	2214	Active	Passed		81	18	68

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
8/4/2023	BEN HALL INT. RSCH	533	Applied Physics Laboratory	2215	Active	Passed		81	18	82
8/4/2023	BEN HALL INT. RSCH	418	Bioengineering	1997	Active	Passed		136	18	62
8/4/2023	BEN HALL INT. RSCH	415	Bioengineering	1996	Active	Passed		123	18	62
8/4/2023	BEN HALL INT. RSCH	409	Bioengineering	1994	Active	Passed		120	18	62
8/4/2023	BEN HALL INT. RSCH	432	Bioengineering	1999	Active	Passed		134	18	62
8/4/2023	BEN HALL INT. RSCH	432	Bioengineering	2000	Active	Passed		126	18	62
8/4/2023	BEN HALL INT. RSCH	432	Bioengineering	2001	Active	Passed		121	18	62
8/4/2023	BEN HALL INT. RSCH	432	Bioengineering	2002	Active	Passed		122	18	62
8/4/2023	BEN HALL INT. RSCH	426	Bioengineering	1998	Active	Passed		116	18	38
8/9/2023	BEN HALL INT. RSCH	620-M	Radiation Oncology	2198	Active	Passed		68	18	53
8/9/2023	BEN HALL INT. RSCH	620F	Radiation Oncology	2185	Active	Passed		62	18	53
8/9/2023	BEN HALL INT. RSCH	620-G	Radiation Oncology	2195	Active	Passed		73	18	53
8/9/2023	BEN HALL INT. RSCH	620-J	Radiation Oncology	2196	Active	Passed		80	18	53
8/11/2023	BEN HALL INT. RSCH	630	Radiation Oncology	2189	Active	Passed		78	18	53
8/11/2023	BEN HALL INT. RSCH	620-L	Radiation Oncology	2197	Active	Passed		87	18	53
8/11/2023	BEN HALL INT. RSCH	630	Radiation Oncology	2188	Active	Passed		69	18	53
8/11/2023	BEN HALL INT. RSCH	630	Radiation Oncology	2192	Active	Passed		89	18	53
8/11/2023	BEN HALL INT. RSCH	680	Radiation Oncology	2051	Active	Passed		78	18	62
8/11/2023	BEN HALL INT. RSCH	680	Radiation Oncology	2052	Active	Passed		86	18	62
8/11/2023	BEN HALL INT. RSCH	630	Radiation Oncology	2187	Active	Passed		94	18	53
8/11/2023	BEN HALL INT. RSCH	630	Radiation Oncology	2200	Active	Passed		76	18	53

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
8/11/2023	BEN HALL INT. RSCH	630	Radiation Oncology	2190	Active	Passed		79	18	53
8/11/2023	BEN HALL INT. RSCH	630	Radiation Oncology	2191	Active	Passed		81	18	53
8/11/2023	BEN HALL INT. RSCH	630	Radiation Oncology	2186	Active	Passed		77	18	53
8/18/2023	BEN HALL INT. RSCH	491	Applied Physics Laboratory	2217	Active	Passed		76	18	62
8/18/2023	BEN HALL INT. RSCH	620-D	Institute for Public Policy and Management	2199	Active	Passed		90	18	53
8/18/2023	BEN HALL INT. RSCH	620-D	Mechanical Engineering	2193	Active	Passed		77	18	53
8/18/2023	BEN HALL INT. RSCH	620-E	Bioengineering	2194	Active	Passed		71	18	53
8/18/2023	BEN HALL INT. RSCH	478C	Civil and Environmental Engineering	2053	Active	Passed		83	18	52
8/18/2023	BEN HALL INT. RSCH	680D	Radiation Oncology	2050	Active	Passed		110	18	62
8/18/2023	BEN HALL INT. RSCH	478B	Civil and Environmental Engineering	2054	Active	Passed		66	18	50
8/23/2023	BEN HALL INT. RSCH	492	Applied Physics Laboratory	2218	Active	Failed		45	18	62
8/25/2023	BEN HALL INT. RSCH	566	Applied Physics Laboratory	2213	Active	Passed		100	18	46
8/25/2023	BEN HALL INT. RSCH	568	Applied Physics Laboratory	2212	Active	Passed		91	18	62
4/19/2023	BENSON HALL	B003B*	Chemical Engineering	1617	Active	Passed		112	18	36
8/2/2024	BENSON HALL	B 20	Chemical Engineering	174	Active	Failed		163	13	60
8/2/2024	BENSON HALL	B013	Chemical Engineering	2165	Active	Passed		93	18	38
8/2/2024	BENSON HALL	121	Chemical Engineering	913	Active	Passed		138	24	48
8/2/2024	BENSON HALL	B033	Chemical Engineering	1858	Active	Passed		99	18	62
8/2/2024	BENSON HALL	127	Chemical Engineering	2161	Active	Failed		79	18	60
8/2/2024	BENSON HALL	B 05	Chemical Engineering	170	Active	Passed		111	23	48
8/2/2024	BENSON HALL	B 05	Chemical Engineering	880	Active	Passed		111	24	64

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
8/2/2024	BENSON HALL	B035	Chemical Engineering	1848	Active	Passed		103	18	62
8/2/2024	BENSON HALL	B035	Chemical Engineering	1849	Active	Passed		110	18	62
8/2/2024	BENSON HALL	B 21	Chemical Engineering	171	Active	Passed		101	18	60
8/2/2024	BENSON HALL	B013	Chemical Engineering	2166	Active	Passed		86	18	38
8/6/2024	BENSON HALL	341	Chemical Engineering	562	Active	Passed		129	18	36
8/6/2024	BENSON HALL	340	Chemical Engineering	561	Active	Passed		112	20	36
8/6/2024	BENSON HALL	336	Chemical Engineering	169	Active	Passed		119	18	48
8/6/2024	BENSON HALL	336	Chemical Engineering	168	Active	Passed		115	18	48
8/6/2024	BENSON HALL	335	Chemical Engineering	560	Active	Passed		98	18	36
8/6/2024	BENSON HALL	231	Chemical Engineering	160	Active	Passed		98	18	36
8/6/2024	BENSON HALL	205	Chemical Engineering	173	Active	Passed		109	18	36
8/6/2024	BENSON HALL	209	Chemical Engineering	156	Active	Passed		100	18	36
8/6/2024	BENSON HALL	211	Chemical Engineering	158	Active	Passed		129	18	36
8/6/2024	BENSON HALL	213	Chemical Engineering	157	Active	Passed		88	18	36
8/6/2024	BENSON HALL	220	Chemical Engineering	159	Active	Passed		125	15	36
8/6/2024	BENSON HALL	235	Chemical Engineering	161	Active	Passed		114	18	36
8/6/2024	BENSON HALL	331	Chemical Engineering	167	Active	Passed		128	18	36
8/6/2024	BENSON HALL	327	Chemical Engineering	565	Active	Passed		137	24	36
8/6/2024	BENSON HALL	247	Chemical Engineering	564	Active	Passed		134	18	36
8/6/2024	BENSON HALL	301	Chemical Engineering	165	Active	Passed		90	18	36
8/6/2024	BENSON HALL	309	Chemical Engineering	162	Active	Passed		114	18	36

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
8/6/2024	BENSON HALL	311	Chemical Engineering	2020	Active	Failed		76	18	38
8/6/2024	BENSON HALL	313	Chemical Engineering	164	Active	Passed		104	24	36
8/6/2024	BENSON HALL	317	Chemical Engineering	163	Active	Passed		129	18	36
8/6/2024	BENSON HALL	227	Chemical Engineering	563	Active	Passed		111	24	36
8/6/2024	BENSON HALL	321	Chemical Engineering	166	Active	Passed		107	24	36
2/7/2024	BLOEDEL HALL	108	Environmental and Forest Sciences	2315	Active	Passed		95	30	28
2/27/2024	BLOEDEL HALL	108	Environmental and Forest Sciences	2314	Active	Passed		66	18	62
2/27/2024	BLOEDEL HALL	178	Environmental and Forest Sciences	1159	Active	Failed		104	28	44
2/27/2024	BLOEDEL HALL	208	Environmental and Forest Sciences	19	Active	Passed		147	24	44
2/27/2024	BLOEDEL HALL	210	Environmental and Forest Sciences	20	Active	Passed		138	18	44
2/27/2024	BLOEDEL HALL	354	Environmental and Forest Sciences	41	Active	Failed		79	18	44
2/28/2024	BLOEDEL HALL	312	Environmental and Forest Sciences	28	Active	Failed		108	28	44
2/28/2024	BLOEDEL HALL	314	Environmental and Forest Sciences	30	Active	Passed		131	28	44
2/28/2024	BLOEDEL HALL	340	Environmental and Forest Sciences	38	Inactive	Failed		107	28	44
2/28/2024	BLOEDEL HALL	308	Environmental and Forest Sciences	27	Active	Passed		115	18	44
3/1/2024	BLOEDEL HALL	313	Environmental and Forest Sciences	29	Active	Passed		110	24	44
3/1/2024	BLOEDEL HALL	M06A	Environmental and Forest Sciences	18	Active	Passed		139	18	35
3/1/2024	BLOEDEL HALL	M016A	Environmental and Forest Sciences	17	Active	Passed		114	18	58
3/1/2024	BLOEDEL HALL	360	Environmental and Forest Sciences	42	Inactive	Failed		4	18	44
3/1/2024	BLOEDEL HALL	337	Environmental and Forest Sciences	1082	Active	Passed		80	28	70
3/1/2024	BLOEDEL HALL	254	Environmental and Forest Sciences	2069	Active	Passed		103	18	40

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
3/1/2024	BLOEDEL HALL	260	Environmental and Forest Sciences	1160	Active	Passed		121	18	44
3/1/2024	BLOEDEL HALL	238	Environmental and Forest Sciences	40	Inactive	Failed		143	18	68
3/1/2024	BLOEDEL HALL	214	Environmental and Forest Sciences	25	Active	Passed		118	24	44
3/1/2024	BLOEDEL HALL	211	Environmental and Forest Sciences	24	Active	Failed		114	21	44
3/1/2024	BLOEDEL HALL	209	Environmental and Forest Sciences	21	Active	Failed		123	24	44
3/1/2024	BLOEDEL HALL	209	Environmental and Forest Sciences	341	Active	Failed		108	24	36
3/1/2024	BLOEDEL HALL	209	Environmental and Forest Sciences	22	Active	Passed		110	24	44
3/1/2024	BLOEDEL HALL	170	Environmental and Forest Sciences	1156	Active	Failed		175	18	44
3/1/2024	BLOEDEL HALL	014	Environmental and Forest Sciences	14	Active	Passed		104	28	44
3/1/2024	BLOEDEL HALL	211	Environmental and Forest Sciences	23	Inactive	Passed		0	0	58
3/1/2024	BLOEDEL HALL	338	Environmental and Forest Sciences	37	Active	Passed		119	28	44
3/1/2024	BLOEDEL HALL	014A	Environmental and Forest Sciences	16	Active	Failed		185	18	58
12/29/2023	Bothell Beardslee	270	School of Medicine	2251	Active	Passed		100	18	62
12/29/2023	Bothell Beardslee	226	School of Medicine	2454	Active	Passed		99	18	72
12/29/2023	Bothell Beardslee	273	School of Medicine	2252	Active	Passed		88	18	38
12/29/2023	Bothell Beardslee	274	School of Medicine	2253	Active	Passed		80	18	62
12/28/2023	Bothell Cascadia 1	CC 340	Science	1767	Active	Passed		104	18	62
12/28/2023	Bothell Cascadia 1	CC 302	Science	1765	Active	Passed		116	18	62
12/28/2023	Bothell Cascadia 1	CC 320	Science	1762	Active	Passed		118	18	62
12/28/2023	Bothell Cascadia 1	CC 330	Science	1764	Active	Passed		111	18	62
12/28/2023	Bothell Cascadia 1	CC 330	Science	1763	Active	Passed		93	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
12/28/2023	Bothell Cascadia 1	CC 331	Science	2234	Active	Passed		100	18	62
12/28/2023	Bothell Cascadia 1	CC 340	Science	1766	Active	Passed		110	18	62
12/27/2023	Bothell Discovery Hall	262	School of STEM	2527	Active	Passed		103	18	70
12/27/2023	Bothell Discovery Hall	469	School of STEM	2512	Active	Passed		109	18	63
12/27/2023	Bothell Discovery Hall	469	School of STEM	2513	Active	Passed		105	18	63
12/27/2023	Bothell Discovery Hall	469	School of STEM	2514	Active	Passed		102	18	63
12/27/2023	Bothell Discovery Hall	463	School of STEM	2503	Active	Passed		73	18	63
12/27/2023	Bothell Discovery Hall	469	School of STEM	2515	Active	Passed		105	18	63
12/27/2023	Bothell Discovery Hall	463	School of STEM	2502	Active	Passed		84	18	63
12/27/2023	Bothell Discovery Hall	469	School of STEM	2516	Active	Passed		86	18	63
12/27/2023	Bothell Discovery Hall	463	School of STEM	2501	Active	Passed		82	18	63
12/27/2023	Bothell Discovery Hall	267	School of STEM	2525	Active	Passed		81	18	63
12/27/2023	Bothell Discovery Hall	380A	School of STEM	2523	Active	Passed		98	18	32
12/27/2023	Bothell Discovery Hall	469	School of STEM	2511	Active	Passed		102	18	63
12/27/2023	Bothell Discovery Hall	463	School of STEM	2504	Active	Passed		81	18	63
12/27/2023	Bothell Discovery Hall	262	School of STEM	2526	Active	Passed		112	18	68
12/27/2023	Bothell Discovery Hall	472	School of STEM	2519	Active	Passed		88	18	36
12/27/2023	Bothell Discovery Hall	367	School of STEM	2521	Active	Passed		76	18	36
12/27/2023	Bothell Discovery Hall	263	School of STEM	2524	Active	Passed		80	18	63
12/27/2023	Bothell Discovery Hall	474	School of STEM	2517	Active	Passed		79	18	63
12/27/2023	Bothell Discovery Hall	474	School of STEM	2518	Active	Passed		81	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
12/27/2023	Bothell Discovery Hall	469	School of STEM	2506	Active	Passed		100	18	63
12/27/2023	Bothell Discovery Hall	467	School of STEM	2505	Active	Passed		74	18	63
12/27/2023	Bothell Discovery Hall	469	School of STEM	2509	Active	Passed		105	18	63
12/27/2023	Bothell Discovery Hall	469	School of STEM	2507	Active	Passed		100	18	63
12/27/2023	Bothell Discovery Hall	469	School of STEM	2508	Active	Passed		104	18	63
12/27/2023	Bothell Discovery Hall	469	School of STEM	2510	Active	Passed		106	18	63
12/28/2023	Bothell UWII (Merrit)	UW2 241	Undergraduate Studies Program	1827	Active	Passed		90	18	62
12/28/2023	Bothell UWII (Merrit)	UW2 241	Undergraduate Studies Program	1826	Active	Passed		101	18	62
12/28/2023	Bothell UWII (Merrit)	UW2 235	Undergraduate Studies Program	1825	Active	Passed		81	18	50
12/28/2023	Bothell UWII (Merrit)	UW2 231	Undergraduate Studies Program	1824	Active	Passed		101	18	50
8/13/2024	Bothell UWII (Merrit)	UW2 231	Undergraduate Studies Program	1823	Active	Passed		87	18	50
1/30/2024	Bowman Building	130*	College of Engineering	2643	Active	Passed		98	32	32
1/30/2024	Bowman Building	130*	College of Engineering	2642	Active	Passed		75	18	86
1/30/2024	Bowman Building	130	Unknown	2641	Active	Passed		75	18	86
4/10/2023	CHDD CLINIC	CD186D	Otolaryngology/Head and Neck Surgery	1553	Active	Passed		23	18	62
10/17/2023	CHDD CLINIC	CD050	Otolaryngology/Head and Neck Surgery	1551	Active	Passed		127	24	62
6/29/2024	CHDD CLINIC	CD186A	Otolaryngology/Head and Neck Surgery	1552	Active	Passed		105	18	62
8/23/2024	CHDD CLINIC	CD198	Neurology	1554	Active	Passed		95	18	62
11/14/2023	Chemistry Building	417A	Chemistry	1446	Active	Failed		116	18	62
11/14/2023	Chemistry Building	427A	Chemistry	1436	Active	Passed		132	18	62
11/14/2023	Chemistry Building	421A	Chemistry	1441	Active	Failed		117	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
11/14/2023	Chemistry Building	421A	Chemistry	1440	Active	Failed		107	18	62
11/14/2023	Chemistry Building	423A	Chemistry	1439	Active	Failed		155	18	62
11/14/2023	Chemistry Building	427A	Chemistry	1438	Active	Failed		111	16	62
11/14/2023	Chemistry Building	427A	Chemistry	1435	Active	Failed		127	16	62
11/14/2023	Chemistry Building	427A	Chemistry	1437	Active	Passed		113	18	62
11/14/2023	Chemistry Building	421A	Chemistry	1442	Active	Passed		125	18	62
11/14/2023	Chemistry Building	421A	Chemistry	1443	Active	Failed		93	18	62
11/14/2023	Chemistry Building	417A	Chemistry	1444	Active	Failed		132	18	62
11/14/2023	Chemistry Building	417A	Chemistry	1445	Active	Failed		153	18	62
11/14/2023	Chemistry Building	417A	Chemistry	1447	Active	Passed		124	18	62
11/27/2023	Chemistry Building	127	Chemistry	1286	Active	Passed		127	18	86
11/27/2023	Chemistry Building	127	Chemistry	1287	Active	Passed		117	18	86
11/27/2023	Chemistry Building	127	Chemistry	1290	Active	Passed		82	18	63
11/27/2023	Chemistry Building	127	Chemistry	1291	Active	Passed		125	18	86
11/27/2023	Chemistry Building	127	Chemistry	1292	Active	Passed		122	18	86
11/27/2023	Chemistry Building	127	Chemistry	1293	Active	Passed		121	18	86
11/27/2023	Chemistry Building	127	Chemistry	1289	Active	Passed		124	18	86
11/27/2023	Chemistry Building	127	Chemistry	1282	Active	Passed		116	18	86
11/27/2023	Chemistry Building	127	Chemistry	1281	Active	Passed		120	18	86
11/27/2023	Chemistry Building	127	Chemistry	1285	Active	Failed		129	18	86
11/27/2023	Chemistry Building	127	Chemistry	1284	Active	Passed		120	18	86

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
11/27/2023	Chemistry Building	127	Chemistry	1283	Active	Passed		126	18	86
11/27/2023	Chemistry Building	127	Chemistry	1288	Active	Passed		130	18	86
11/30/2023	Chemistry Building	414A	Chemistry	1421	Active	Passed		144	18	62
11/30/2023	Chemistry Building	418A	Chemistry	1425	Active	Failed		94	18	62
11/30/2023	Chemistry Building	418A	Chemistry	1424	Active	Failed		133	18	62
11/30/2023	Chemistry Building	411A	Chemistry	1452	Active	Passed		139	18	62
11/30/2023	Chemistry Building	411A	Chemistry	1451	Active	Failed		151	18	62
11/30/2023	Chemistry Building	411A	Chemistry	1449	Active	Failed		146	18	62
11/30/2023	Chemistry Building	411A	Chemistry	1450	Active	Failed		113	18	62
11/30/2023	Chemistry Building	413A	Chemistry	1448	Active	Passed		110	18	62
11/30/2023	Chemistry Building	418A	Chemistry	1422	Active	Passed		104	18	62
11/30/2023	Chemistry Building	412A	Chemistry	1419	Active	Failed		100	18	62
11/30/2023	Chemistry Building	412A	Chemistry	1418	Active	Passed		89	18	62
11/30/2023	Chemistry Building	418A	Chemistry	1423	Active	Failed		129	18	62
11/30/2023	Chemistry Building	412A	Chemistry	1417	Active	Failed		103	18	62
11/30/2023	Chemistry Building	412A	Chemistry	1420	Active	Failed		145	18	62
12/1/2023	Chemistry Building	111	Chemistry	1267	Active	Passed		107	18	86
12/1/2023	Chemistry Building	111	Chemistry	1270	Active	Passed		114	24	38
12/1/2023	Chemistry Building	111	Chemistry	1266	Active	Passed		108	18	86
12/1/2023	Chemistry Building	111	Chemistry	1279	Active	Passed		112	18	86
12/1/2023	Chemistry Building	111	Chemistry	1278	Active	Passed		123	18	86

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
12/1/2023	Chemistry Building	111	Chemistry	1269	Active	Passed		115	18	38
12/1/2023	Chemistry Building	111	Chemistry	1268	Active	Passed		106	18	86
12/1/2023	Chemistry Building	111	Chemistry	1271	Active	Passed		87	18	62
12/1/2023	Chemistry Building	111	Chemistry	1272	Active	Passed		116	18	86
12/1/2023	Chemistry Building	111	Chemistry	1273	Active	Passed		111	18	86
12/1/2023	Chemistry Building	111	Chemistry	1274	Active	Passed		115	18	86
12/1/2023	Chemistry Building	111	Chemistry	1275	Active	Passed		105	18	86
12/1/2023	Chemistry Building	111	Chemistry	1276	Active	Passed		120	18	86
12/1/2023	Chemistry Building	111	Chemistry	1277	Active	Passed		122	18	86
12/5/2023	Chemistry Building	428A	Chemistry	1431	Active	Passed		150	16	62
12/5/2023	Chemistry Building	424A	Chemistry	1430	Active	Failed		159	20	62
12/5/2023	Chemistry Building	428A	Chemistry	1432	Active	Failed		141	18	62
12/5/2023	Chemistry Building	428A	Chemistry	1433	Active	Failed		157	18	62
12/5/2023	Chemistry Building	422A	Chemistry	1426	Active	Passed		127	18	62
12/5/2023	Chemistry Building	422A	Chemistry	1427	Active	Failed		135	18	62
12/5/2023	Chemistry Building	422A	Chemistry	1429	Active	Failed		104	18	62
12/5/2023	Chemistry Building	422A	Chemistry	1428	Active	Passed		109	18	62
12/5/2023	Chemistry Building	428A	Chemistry	1434	Active	Failed		156	18	62
12/6/2023	Chemistry Building	214A	Chemistry	1345	Active	Failed		172	18	62
12/6/2023	Chemistry Building	228A	Chemistry	1358	Active	Failed		84	18	62
12/6/2023	Chemistry Building	228A	Chemistry	1357	Active	Failed		77	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
12/6/2023	Chemistry Building	228A	Chemistry	1355	Active	Failed		105	18	62
12/6/2023	Chemistry Building	228A	Chemistry	1356	Active	Failed		92	18	62
12/6/2023	Chemistry Building	224A	Chemistry	1354	Active	Failed		145	24	62
12/6/2023	Chemistry Building	222A	Chemistry	1353	Active	Failed		106	18	62
12/6/2023	Chemistry Building	222A	Chemistry	1352	Active	Passed		108	18	62
12/6/2023	Chemistry Building	222A	Chemistry	1350	Active	Failed		109	18	62
12/6/2023	Chemistry Building	222A	Chemistry	1351	Active	Failed		100	18	62
12/8/2023	Chemistry Building	128	Chemistry	1322	Active	Passed		123	18	86
12/8/2023	Chemistry Building	128	Chemistry	1311	Active	Passed		112	18	86
12/8/2023	Chemistry Building	128	Chemistry	1321	Active	Passed		93	18	86
12/8/2023	Chemistry Building	128	Chemistry	1320	Active	Passed		109	18	86
12/8/2023	Chemistry Building	128	Chemistry	1319	Active	Passed		128	18	86
12/8/2023	Chemistry Building	128	Chemistry	1318	Active	Passed		113	18	86
12/8/2023	Chemistry Building	128	Chemistry	1317	Active	Failed		141	18	86
12/8/2023	Chemistry Building	128	Chemistry	1314	Active	Passed		101	18	86
12/8/2023	Chemistry Building	128	Chemistry	1315	Active	Passed		85	18	86
12/8/2023	Chemistry Building	128	Chemistry	1316	Active	Passed		124	18	86
12/8/2023	Chemistry Building	128	Chemistry	1313	Active	Passed		99	18	86
12/8/2023	Chemistry Building	128	Chemistry	1312	Active	Passed		128	18	86
12/8/2023	Chemistry Building	128	Chemistry	1323	Active	Passed		116	18	86
12/11/2023	Chemistry Building	112	Chemistry	1307	Active	Passed		99	18	86

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
12/11/2023	Chemistry Building	112	Chemistry	1297	Active	Passed		112	18	86
12/11/2023	Chemistry Building	112	Chemistry	1308	Active	Passed		93	18	86
12/11/2023	Chemistry Building	112	Chemistry	1306	Active	Passed		89	18	62
12/11/2023	Chemistry Building	112	Chemistry	1305	Active	Passed		117	18	86
12/11/2023	Chemistry Building	112	Chemistry	1304	Active	Passed		122	18	86
12/11/2023	Chemistry Building	112	Chemistry	1303	Active	Passed		113	18	86
12/11/2023	Chemistry Building	112	Chemistry	1302	Active	Passed		116	18	86
12/11/2023	Chemistry Building	112	Chemistry	1301	Active	Passed		120	18	86
12/11/2023	Chemistry Building	112	Chemistry	1300	Active	Passed		101	18	74
12/11/2023	Chemistry Building	112	Chemistry	1299	Active	Passed		97	18	86
12/11/2023	Chemistry Building	112	Chemistry	1298	Active	Passed		110	18	86
12/11/2023	Chemistry Building	112	Chemistry	1309	Active	Passed		99	18	86
12/13/2023	Chemistry Building	G024	Chemistry	1331	Active	Passed		98	18	50
12/13/2023	Chemistry Building	118	Chemistry	1310	Active	Failed		100	18	62
12/13/2023	Chemistry Building	108	Chemistry	1294	Active	Failed		134	18	50
12/13/2023	Chemistry Building	104	Chemistry	1296	Active	Passed		123	24	38
12/13/2023	Chemistry Building	G003	Chemistry	1455	Active	Passed		119	19	50
12/13/2023	Chemistry Building	G002	Chemistry	1325	Active	Failed		95	18	50
12/13/2023	Chemistry Building	G006	Chemistry	1326	Active	Failed		101	18	50
12/13/2023	Chemistry Building	G012A	Chemistry	1327	Active	Passed		102	18	50
12/13/2023	Chemistry Building	121A	Chemistry	1280	Active	Passed		87	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
12/13/2023	Chemistry Building	G022	Chemistry	1329	Active	Failed		138	18	50
12/13/2023	Chemistry Building	108	Chemistry	1295	Active	Failed		122	18	50
12/13/2023	Chemistry Building	218A	Chemistry	1349	Active	Passed		93	18	62
12/13/2023	Chemistry Building	218A	Chemistry	1348	Active	Failed		79	18	62
12/13/2023	Chemistry Building	218A	Chemistry	1346	Active	Failed		117	18	62
12/13/2023	Chemistry Building	218A	Chemistry	1347	Active	Failed		82	18	62
12/13/2023	Chemistry Building	212A	Chemistry	1342	Active	Failed		111	18	62
12/13/2023	Chemistry Building	212A	Chemistry	1341	Active	Failed		120	18	62
12/13/2023	Chemistry Building	212A	Chemistry	1343	Active	Failed		88	18	62
12/13/2023	Chemistry Building	212A	Chemistry	1344	Active	Failed		102	18	62
12/13/2023	Chemistry Building	G018	Chemistry	1330	Active	Failed		108	18	50
12/13/2023	Chemistry Building	G003	Chemistry	1454	Active	Passed		118	19	50
12/15/2023	Chemistry Building	223A	Chemistry	1363	Active	Passed		100	18	62
12/15/2023	Chemistry Building	227A	Chemistry	1359	Active	Passed		86	18	62
12/15/2023	Chemistry Building	227A	Chemistry	1360	Active	Failed		105	18	62
12/15/2023	Chemistry Building	227A	Chemistry	1361	Active	Failed		103	18	62
12/15/2023	Chemistry Building	221A	Chemistry	1364	Active	Failed		100	18	62
12/15/2023	Chemistry Building	221A	Chemistry	1365	Active	Failed		99	18	62
12/15/2023	Chemistry Building	221A	Chemistry	1367	Active	Failed		98	18	62
12/15/2023	Chemistry Building	221A	Chemistry	1366	Active	Failed		113	18	62
12/15/2023	Chemistry Building	217A	Chemistry	1371	Active	Failed		100	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
12/15/2023	Chemistry Building	211A	Chemistry	1374	Active	Failed		101	18	62
12/15/2023	Chemistry Building	227A	Chemistry	1362	Active	Passed		110	18	62
12/15/2023	Chemistry Building	217A	Chemistry	1370	Active	Failed		98	18	62
12/15/2023	Chemistry Building	211A	Chemistry	1373	Active	Passed		100	18	62
12/15/2023	Chemistry Building	211A	Chemistry	1375	Active	Failed		112	18	62
12/15/2023	Chemistry Building	211A	Chemistry	1376	Active	Failed		121	18	62
12/15/2023	Chemistry Building	213A	Chemistry	1372	Active	Passed		107	18	62
12/15/2023	Chemistry Building	217A	Chemistry	1368	Active	Failed		94	18	62
12/15/2023	Chemistry Building	217A	Chemistry	1369	Active	Failed		98	18	62
12/21/2023	Chemistry Building	311A	Chemistry	1411	Active	Failed		106	18	62
12/21/2023	Chemistry Building	327A	Chemistry	1398	Active	Passed		108	18	62
12/21/2023	Chemistry Building	321A	Chemistry	1405	Active	Passed		89	18	62
12/21/2023	Chemistry Building	317A	Chemistry	1407	Active	Passed		105	18	62
12/21/2023	Chemistry Building	317A	Chemistry	1408	Active	Failed		100	18	62
12/21/2023	Chemistry Building	317A	Chemistry	1409	Active	Passed		111	18	62
12/21/2023	Chemistry Building	327A	Chemistry	1400	Active	Failed		119	18	62
12/21/2023	Chemistry Building	321A	Chemistry	1404	Active	Passed		104	18	62
12/21/2023	Chemistry Building	321A	Chemistry	1403	Active	Failed		103	18	62
12/21/2023	Chemistry Building	321A	Chemistry	1402	Active	Failed		113	18	62
12/21/2023	Chemistry Building	323A	Chemistry	1401	Active	Failed		157	20	62
12/21/2023	Chemistry Building	327A	Chemistry	1397	Active	Passed		108	16	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
12/21/2023	Chemistry Building	311A	Chemistry	1413	Active	Failed		116	18	62
12/21/2023	Chemistry Building	311A	Chemistry	1412	Active	Failed		106	18	62
12/21/2023	Chemistry Building	313A	Chemistry	1410	Active	Passed		135	24	62
12/21/2023	Chemistry Building	317A	Chemistry	1406	Active	Failed		111	18	62
12/21/2023	Chemistry Building	311A	Chemistry	1414	Active	Passed		114	18	62
12/21/2023	Chemistry Building	327A	Chemistry	1399	Active	Passed		112	18	62
12/26/2023	Chemistry Building	328A	Chemistry	1395	Active	Passed		114	18	62
12/26/2023	Chemistry Building	314A	Chemistry	1383	Active	Failed		128	13	62
12/26/2023	Chemistry Building	318A	Chemistry	1387	Active	Failed		113	18	62
12/26/2023	Chemistry Building	324A	Chemistry	1392	Active	Passed		109	24	62
12/26/2023	Chemistry Building	318A	Chemistry	1385	Active	Passed		78	18	62
12/26/2023	Chemistry Building	312A	Chemistry	1380	Active	Passed		106	18	62
12/26/2023	Chemistry Building	312A	Chemistry	1381	Active	Failed		72	18	62
12/26/2023	Chemistry Building	318A	Chemistry	1386	Active	Passed		96	18	62
12/26/2023	Chemistry Building	318A	Chemistry	1384	Active	Passed		85	18	62
12/26/2023	Chemistry Building	328A	Chemistry	1396	Active	Failed		106	18	62
12/26/2023	Chemistry Building	328A	Chemistry	1394	Active	Passed		109	18	62
12/26/2023	Chemistry Building	312A	Chemistry	1382	Active	Failed		105	17	62
12/26/2023	Chemistry Building	312A	Chemistry	1379	Active	Failed		106	18	62
12/26/2023	Chemistry Building	322A	Chemistry	1391	Active	Failed		87	18	62
12/26/2023	Chemistry Building	322A	Chemistry	1390	Active	Failed		95	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
12/26/2023	Chemistry Building	322A	Chemistry	1389	Active	Failed		90	18	62
12/26/2023	Chemistry Building	322A	Chemistry	1388	Active	Failed		95	18	62
12/26/2023	Chemistry Building	328A	Chemistry	1393	Active	Passed		135	17	62
12/28/2023	Chemistry Building	205B	Chemistry	1339	Active	Passed		113	18	50
12/28/2023	Chemistry Building	G045	Chemistry	1334	Active	Passed		126	18	50
12/28/2023	Chemistry Building	G051	Chemistry	1530	Active	Passed		96	18	50
12/28/2023	Chemistry Building	405B	Chemistry	1416	Active	Passed		83	18	50
12/28/2023	Chemistry Building	G011	Chemistry	1338	Active	Passed		103	18	50
12/28/2023	Chemistry Building	305B	Chemistry	1378	Active	Passed		112	18	50
12/28/2023	Chemistry Building	305B	Chemistry	1377	Active	Passed		112	18	50
12/28/2023	Chemistry Building	G028	Chemistry	1332	Active	Failed		120	18	50
12/28/2023	Chemistry Building	G027	Chemistry	1335	Active	Failed		116	18	50
12/28/2023	Chemistry Building	G017	Chemistry	1337	Active	Failed		127	18	62
12/28/2023	Chemistry Building	205B	Chemistry	1340	Active	Passed		129	18	50
12/28/2023	Chemistry Building	G055	Chemistry	1333	Active	Passed		81	18	50
12/28/2023	Chemistry Building	G014	Chemistry	1328	Active	Passed		132	18	50
12/28/2023	Chemistry Building	405B	Chemistry	1415	Active	Passed		83	18	50
1/2/2024	Chemistry Building	G021	Chemistry	1336	Active	Failed		122	18	50
5/31/2024	CHEMISTRY LIBRARY	140	Chemistry	996	Active	Passed		105	28	38
5/31/2024	CHEMISTRY LIBRARY	121	Chemistry	1057	Active	Passed		133	18	38
5/31/2024	CHEMISTRY LIBRARY	156A	Chemistry	997	Active	Passed		102	28	38

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
3/29/2024	CTR URBAN WATERS	324	Envirnomenta Scienes UWT	2225	Active	Passed		87	17	62
3/29/2024	CTR URBAN WATERS	320	Health Services	2221	Active	Passed		79	17	62
3/29/2024	CTR URBAN WATERS	323	Envirnomenta Scienes UWT	2222	Active	Passed		88	17	82
3/29/2024	CTR URBAN WATERS	323	Envirnomenta Scienes UWT	2223	Active	Passed		86	17	82
3/29/2024	CTR URBAN WATERS	323	Envirnomenta Scienes UWT	2224	Active	Passed		81	17	82
3/29/2024	CTR URBAN WATERS	324	Environmental Health	2226	Active	Passed		78	17	62
3/29/2024	CTR URBAN WATERS	329	Envirnomenta Scienes UWT	2227	Active	Passed		87	17	62
10/11/2023	DENNY HALL	456A	Anthropology	2547	Active	Passed		79	20	63
2/7/2023	Douglas Research Cons.	112J	Urban Horticulture Division	1112	Active	Passed		130	18	38
4/10/2024	Douglas Research Cons.	112K	Urban Horticulture Division	1115	Active	Passed		95	18	38
10/9/2024	ELECTRICAL ENG BLDG	B030	Electrical Engineering	1597	Active	Passed		102	28	62
10/9/2024	ELECTRICAL ENG BLDG	B023B	Electrical Engineering	1593	Active	Passed		121	28	62
10/9/2024	ELECTRICAL ENG BLDG	B029A	Electrical Engineering	1596	Active	Passed		100	28	62
10/9/2024	ELECTRICAL ENG BLDG	B039A	Electrical Engineering	1605	Active	Passed		110	28	62
10/9/2024	ELECTRICAL ENG BLDG	B023A	Electrical Engineering	1594	Active	Passed		115	28	62
10/9/2024	ELECTRICAL ENG BLDG	065	Electrical Engineering	1855	Active	Passed		110	28	62
10/9/2024	ELECTRICAL ENG BLDG	B024A	Electrical Engineering	1603	Active	Passed		104	28	62
10/9/2024	ELECTRICAL ENG BLDG	B031A	Electrical Engineering	1598	Active	Passed		115	28	62
10/9/2024	ELECTRICAL ENG BLDG	B023A	Electrical Engineering	1595	Active	Passed		113	28	62
10/9/2024	ELECTRICAL ENG BLDG	B037A	Electrical Engineering	1604	Active	Passed		115	28	62
10/9/2024	ELECTRICAL ENG BLDG	059A	Electrical Engineering	1592	Active	Passed		86	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/9/2024	ELECTRICAL ENG BLDG	B052A	Electrical Engineering	1599	Active	Passed		120	28	62
10/9/2024	ELECTRICAL ENG BLDG	B042A	Electrical Engineering	1600	Active	Passed		118	28	62
8/24/2023	ENGINEERING ANNEX	222A	Bioengineering	44	Active	Passed		101	18	60
8/29/2023	ENGINEERING ANNEX	215	Mechanical Engineering	1161	Active	Passed		98	18	60
7/18/2024	ENVIRON STOR BLDG	105	Environmental Health and Safety	2258	Active	Passed		84	18	87
7/18/2024	ENVIRON STOR BLDG	105	Environmental Health and Safety	1087	Active	Passed		100	18	62
7/18/2024	ENVIRON STOR BLDG	108	Environmental Health and Safety	2259	Active	Passed		78	18	87
7/18/2024	ENVIRON STOR BLDG	104	Environmental Health and Safety	1086	Active	Passed		107	18	62
6/5/2024	Fisheries Teach/Research	125	School of Fisheries	1062	Active	Passed		122	18	52
6/5/2024	Fisheries Teach/Research	209	School of Fisheries	1064	Active	Passed		102	18	52
6/5/2024	Fisheries Teach/Research	213	School of Fisheries	1820	Active	Passed		116	18	52
6/5/2024	Fisheries Teach/Research	224	School of Fisheries	1065	Active	Passed		118	18	52
6/5/2024	Fisheries Teach/Research	225	School of Fisheries	1067	Active	Passed		130	18	64
6/5/2024	Fisheries Teach/Research	228	School of Fisheries	1066	Active	Passed		144	18	52
6/5/2024	Fisheries Teach/Research	229	School of Fisheries	1531	Active	Passed		145	18	52
6/5/2024	Fisheries Teach/Research	113	School of Fisheries	1061	Active	Passed		100	18	52
6/5/2024	Fisheries Teach/Research	124	School of Fisheries	1076	Active	Failed		166	18	52
6/11/2024	FISHERY SCIENCES	146A	School of Fisheries	1682	Active	Passed		140	18	63
6/11/2024	FISHERY SCIENCES	334	School of Fisheries	1689	Active	Passed		116	18	63
6/11/2024	FISHERY SCIENCES	332	School of Fisheries	1688	Active	Passed		102	18	63
6/11/2024	FISHERY SCIENCES	248	School of Fisheries	1687	Active	Passed		115	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
6/11/2024	FISHERY SCIENCES	246	School of Fisheries	1686	Active	Passed		104	18	63
6/11/2024	FISHERY SCIENCES	340	School of Fisheries	1690	Active	Passed		91	18	68
6/11/2024	FISHERY SCIENCES	236	School of Fisheries	1684	Active	Passed		112	18	68
6/11/2024	FISHERY SCIENCES	142	School of Fisheries	1680	Active	Passed		111	18	38
6/11/2024	FISHERY SCIENCES	242	School of Fisheries	1685	Active	Failed		165	18	63
6/11/2024	FISHERY SCIENCES	342	School of Fisheries	1691	Active	Passed		114	18	62
6/11/2024	FISHERY SCIENCES	346	School of Fisheries	1692	Active	Passed		121	18	62
6/11/2024	FISHERY SCIENCES	232	School of Fisheries	1683	Active	Passed		128	18	63
6/11/2024	FISHERY SCIENCES	142	School of Fisheries	1679	Active	Passed		144	18	38
6/11/2024	FISHERY SCIENCES	142	School of Fisheries	1678	Active	Passed		111	18	38
6/11/2024	FISHERY SCIENCES	139	School of Fisheries	1677	Active	Passed		121	18	63
6/11/2024	FISHERY SCIENCES	138	School of Fisheries	1676	Active	Passed		123	18	62
6/11/2024	FISHERY SCIENCES	132	School of Fisheries	1675	Active	Passed		146	18	62
6/11/2024	FISHERY SCIENCES	348	School of Fisheries	1693	Active	Passed		98	18	62
6/11/2024	FISHERY SCIENCES	142	School of Fisheries	1681	Active	Failed		173	18	63
3/9/2023	FLUKE HALL	225	CoMotion (C4C New Ventures)	1143	Active	Passed		118	19	38
6/26/2024	FLUKE HALL	225	CoMotion (C4C New Ventures)	1145	Active	Passed		112	18	50
6/26/2024	FLUKE HALL	225	CoMotion (C4C New Ventures)	1144	Active	Passed		114	18	38
6/26/2024	FLUKE HALL	225	CoMotion (C4C New Ventures)	1147	Active	Passed		103	18	50
6/26/2024	FLUKE HALL	225	CoMotion (C4C New Ventures)	1146	Active	Passed		101	18	50
6/26/2024	FLUKE HALL	235	Mechanical Engineering	1743	Active	Passed		112	18	88

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
6/26/2024	FLUKE HALL	235	Mechanical Engineering	1149	Active	Passed		113	18	38
6/26/2024	FLUKE HALL	239B	CoMotion (C4C New Ventures)	1150	Active	Passed		95	18	50
6/26/2024	FLUKE HALL	225	CoMotion (C4C New Ventures)	1148	Active	Passed		102	18	38
11/14/2023	Fri Hrb Computer Lab	CL-101	Biology Program	1619	Active	Failed		126	18	36
11/14/2023	FRI HRB FERNALD LAB	108	Biology Program	1618	Active	Passed		100	18	48
11/14/2023	FRI HRB LAB 08	8-112	Biology Program	1620	Active	Passed		92	18	48
11/14/2023	FRI HRB LAB 10	204	Biology Program	1836	Active	Passed		91	18	40
11/14/2023	FRI HRB LAB 10	10-108	Biology Program	1835	Active	Passed		114	16	40
11/14/2023	FRI HRB LAB 12	104	Biology Program	2220	Active	Passed		100	18	36
8/24/2023	GATES CTR FOR CSE	352A	Computer Science and Engineering	2638	Active	Passed		86	18	87
10/15/2024	GUGGENHEIM HALL	107	Aeronautics and Astronautics	2216	Active	Passed		109	18	38
2/16/2024	GUTHRIE HALL	414	Psychology	2540	Active	Passed		123	18	38
2/16/2024	GUTHRIE HALL	360	Psychology	2537	Active	Passed		97	18	63
2/16/2024	GUTHRIE HALL	361	Psychology	2538	Active	Passed		116	18	63
2/16/2024	GUTHRIE HALL	361	Psychology	2539	Active	Passed		83	18	63
2/16/2024	GUTHRIE HALL	401	Psychology	2541	Active	Failed		157	18	44
2/20/2024	GUTHRIE HALL	354A	Psychology	2536	Active	Passed		113	18	63
1/29/2024	HARBORVIEW MED CNTR	GWH-47	Laboratory Medicine	1581	Active	Passed		129	18	38
1/29/2024	HARBORVIEW MED CNTR	GWH-47	Laboratory Medicine	1578	Active	Failed		165	18	84
1/29/2024	HARBORVIEW MED CNTR	GWH-47	Laboratory Medicine	1579	Active	Passed		135	18	84
1/29/2024	HARBORVIEW MED CNTR	GWH-47	Laboratory Medicine	1580	Active	Failed		156	18	84

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
1/29/2024	HARBORVIEW MED CNTR	2EC-22	Environmental Health and Safety	1630	Active	Passed		91	18	62
5/24/2024	HARBORVIEW MED CNTR	GWH-47	Laboratory Medicine	1575	Active	Failed		71	18	84
5/24/2024	HARBORVIEW MED CNTR	GWH-47	Laboratory Medicine	1576	Active	Failed		184	18	84
5/24/2024	HARBORVIEW MED CNTR	GWH-47	Laboratory Medicine	1577	Active	Passed		118	18	84
1/30/2024	HARBORVIEW NJB	2NJ-272	Pathology	2170	Active	Passed		100	18	64
1/30/2024	HARBORVIEW NJB	3NJ-317.9	School of Medicine	2179	Active	Passed		95	18	64
1/30/2024	HARBORVIEW NJB	3NJ-317	School of Medicine	2178	Active	Passed		87	18	64
1/30/2024	HARBORVIEW NJB	2NJ-271	Pathology	2671	Active	Passed		113	8	
1/30/2024	HARBORVIEW NJB	2NJ-272	Pathology	2168	Active	Passed		107	18	64
1/30/2024	HARBORVIEW NJB	2NJ-274	Pathology	2173	Active	Passed		96	18	64
1/30/2024	HARBORVIEW NJB	2NJ-272	Pathology	2169	Active	Passed		93	18	40
1/30/2024	HARBORVIEW NJB	3NJ-317.10	School of Medicine	2180	Active	Passed		93	18	64
1/30/2024	HARBORVIEW NJB	2NJ-270	Pathology	2172	Active	Passed		81	18	64
1/30/2024	HARBORVIEW NJB	2NJ-270	Pathology	2171	Active	Passed		85	18	64
1/30/2024	HARBORVIEW NJB	3NJ-342.7	School of Medicine	2182	Active	Passed		95	18	64
1/30/2024	HARBORVIEW NJB	3NJ-342.7	School of Medicine	2181	Active	Passed		105	18	64
1/30/2024	HARBORVIEW NJB	3NJ-324	School of Medicine	2183	Active	Passed		127	18	40
1/30/2024	HARBORVIEW NJB	2NJ-274	Pathology	2174	Active	Passed		82	18	64
1/30/2024	HARBORVIEW NJB	2NJ-274	Pathology	2175	Active	Passed		89	18	64
1/30/2024	HARBORVIEW NJB	2NJ-269	Pathology	2167	Active	Passed		84	18	52
4/4/2023	HARBORVIEW R&T	SB049	Comparative Medicine	1669	Active	Passed		126	18	38

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/3/2023	HARBORVIEW R&T	312	Harborview Medical Center	1664	Active	Failed		360	18	62
10/3/2023	HARBORVIEW R&T	313	Harborview Medical Center	1663	Active	Passed		111	18	62
10/3/2023	HARBORVIEW R&T	418	Harborview Medical Center	1654	Active	Passed		113	18	62
10/3/2023	HARBORVIEW R&T	326	Harborview Medical Center	1660	Active	Passed		111	18	62
10/3/2023	HARBORVIEW R&T	426	Harborview Medical Center	1655	Active	Passed		119	18	62
10/3/2023	HARBORVIEW R&T	427	Harborview Medical Center	1657	Active	Passed		114	18	62
10/3/2023	HARBORVIEW R&T	421	Harborview Medical Center	1658	Active	Passed		122	18	62
10/3/2023	HARBORVIEW R&T	413	Harborview Medical Center	1659	Active	Passed		121	18	62
10/3/2023	HARBORVIEW R&T	420E	Harborview Medical Center	1656	Active	Passed		120	18	62
10/3/2023	HARBORVIEW R&T	410	Harborview Medical Center	1653	Active	Passed		121	18	62
10/3/2023	HARBORVIEW R&T	321	Harborview Medical Center	1662	Active	Passed		112	18	62
10/3/2023	HARBORVIEW R&T	327	Harborview Medical Center	1661	Active	Passed		112	18	62
10/4/2023	HARBORVIEW R&T	510	Harborview Medical Center	1647	Active	Failed		334	18	62
10/4/2023	HARBORVIEW R&T	627	Harborview Medical Center	1646	Active	Failed		127	18	62
10/4/2023	HARBORVIEW R&T	621	Harborview Medical Center	1645	Active	Passed		116	18	62
10/4/2023	HARBORVIEW R&T	613	Harborview Medical Center	1644	Active	Passed		119	18	62
10/4/2023	HARBORVIEW R&T	526	Harborview Medical Center	1649	Active	Passed		114	18	62
10/4/2023	HARBORVIEW R&T	518	Harborview Medical Center	1648	Active	Passed		105	18	62
10/4/2023	HARBORVIEW R&T	521	Harborview Medical Center	1651	Active	Passed		116	18	62
10/4/2023	HARBORVIEW R&T	527	Harborview Medical Center	1650	Active	Passed		112	18	62
10/5/2023	HARBORVIEW R&T	713	Harborview Medical Center	1639	Active	Passed		109	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/5/2023	HARBORVIEW R&T	715A	Medicine	1819	Active	Failed		257	18	40
10/5/2023	HARBORVIEW R&T	B008	Pathology	2055	Active	Passed		105	18	62
10/5/2023	HARBORVIEW R&T	710	Harborview Medical Center	1674	Active	Passed		114	18	62
10/5/2023	HARBORVIEW R&T	B010	Harborview Medical Center	1666	Active	Passed		112	18	38
10/5/2023	HARBORVIEW R&T	B004	Harborview Medical Center	1665	Active	Passed		108	18	38
10/5/2023	HARBORVIEW R&T	718	Harborview Medical Center	1637	Active	Passed		107	18	62
10/5/2023	HARBORVIEW R&T	726	Harborview Medical Center	1638	Active	Passed		109	18	62
10/5/2023	HARBORVIEW R&T	626	Harborview Medical Center	1642	Active	Passed		115	18	62
10/5/2023	HARBORVIEW R&T	618	Harborview Medical Center	1641	Active	Passed		104	18	62
10/5/2023	HARBORVIEW R&T	610	Harborview Medical Center	1640	Active	Passed		112	18	62
10/5/2023	HARBORVIEW R&T	B016	Harborview Medical Center	1667	Active	Passed		109	18	38
10/5/2023	HARBORVIEW R&T	B018	Comparative Medicine	1816	Active	Failed		122	18	40
10/5/2023	HARBORVIEW R&T	B018	Comparative Medicine	1817	Active	Failed		124	18	40
10/5/2023	HARBORVIEW R&T	620E	Harborview Medical Center	1643	Active	Failed		41	18	38
10/5/2023	HARBORVIEW R&T	513	Harborview Medical Center	1652	Active	Passed		108	18	62
8/23/2024	HARBORVIEW R&T	SB011	Comparative Medicine	1673	Active	Passed		88	18	38
8/23/2024	HARBORVIEW R&T	SB044	Comparative Medicine	1668	Active	Passed		112	18	38
8/23/2024	HARBORVIEW R&T	SB023	Harborview Medical Center	1670	Active	Passed		124	18	38
8/23/2024	HARBORVIEW R&T	SB011	Comparative Medicine	1671	Active	Passed		92	18	38
8/23/2024	HARBORVIEW R&T	SB011	Harborview Medical Center	1672	Active	Passed		99	18	38
3/29/2024	HENDERSON HALL (APL)	HH 301D	Applied Physics Laboratory	1915	Active	Failed		109	18	40

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
8/28/2024	HITCHCOCK HALL	413	Biology Program	695	Active	Failed		51	28	58
8/28/2024	HITCHCOCK HALL	520A	Biology Program	698	Active	Failed		26	23	58
8/28/2024	HITCHCOCK HALL	105	Biology Program	925	Active	Passed		121	28	48
8/28/2024	HITCHCOCK HALL	123	Biology Program	678	Active	Passed		143	27	48
8/28/2024	HITCHCOCK HALL	128	Biology Program	679	Active	Passed		133	28	36
8/28/2024	HITCHCOCK HALL	520A	Biology Program	699	Active	Passed		127	18	36
8/28/2024	HITCHCOCK HALL	423	Biology Program	931	Active	Failed		10	18	58
8/28/2024	HITCHCOCK HALL	543A	Biology Program	700	Active	Passed		110	28	58
8/28/2024	HITCHCOCK HALL	347A	Biology Program	691	Active	Passed		119	28	48
8/28/2024	HITCHCOCK HALL	346A	Biology Program	690	Active	Passed		124	18	48
8/28/2024	HITCHCOCK HALL	244A	Biology Program	686	Active	Passed		99	26	48
8/28/2024	HITCHCOCK HALL	544A	Biology Program	927	Active	Passed		111	24	48
8/28/2024	HITCHCOCK HALL	144A	Biology Program	681	Active	Passed		129	26	48
8/28/2024	HITCHCOCK HALL	444A	Biology Program	692	Active	Passed		144	24	48
8/28/2024	HITCHCOCK HALL	143A	Biology Program	680	Active	Passed		121	27	48
8/28/2024	HITCHCOCK HALL	507	Biology Program	697	Active	Failed		4	24	48
8/28/2024	HITCHCOCK HALL	516	Biology Program	1097	Active	Passed		114	24	48
8/28/2024	HITCHCOCK HALL	522	Biology Program	926	Active	Passed		114	18	58
8/28/2024	HITCHCOCK HALL	413	Biology Program	694	Active	Failed		49	28	36
8/29/2024	HITCHCOCK HALL	506	Biology Program	696	Active	Passed		99	24	48
8/29/2024	HITCHCOCK HALL	014	Biochemistry	219	Active	Passed		122	18	60

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
8/29/2024	HITCHCOCK HALL	307	Biology Program	687	Active	Passed		117	20	48
8/29/2024	HITCHCOCK HALL	523	Biology Program	685	Active	Passed		98	28	48
8/29/2024	HITCHCOCK HALL	218	Biology Program	682	Active	Passed		118	28	48
8/30/2024	HITCHCOCK HALL	309	Biology Program	688	Active	Failed		25	18	58
8/30/2024	HITCHCOCK HALL	309	Biology Program	689	Active	Failed		75	18	36
11/1/2024	HITCHCOCK HALL	243A	Biology Program	684	Active	Failed		153	28	48
11/1/2024	HITCHCOCK HALL	223	Biology Program	821	Inactive	Passed		0	0	84
11/1/2024	HITCHCOCK HALL	302	Biology Program	1118	Inactive	Passed		0	0	36
12/22/2023	Innovation Lab	315	Unknown	2688	Active	Passed		100	18	63
12/22/2023	Innovation Lab	315	Unknown	2684	Active	Passed		89	18	63
12/22/2023	Innovation Lab	315	Unknown	2681	Active	Passed		108	18	63
12/22/2023	Innovation Lab	315	Unknown	2682	Active	Passed		98	18	63
12/22/2023	Innovation Lab	315	Unknown	2685	Active	Passed		109	18	63
12/22/2023	Innovation Lab	315	Unknown	2686	Active	Passed		94	18	63
12/22/2023	Innovation Lab	333	Unknown	2693	Active	Passed		85	18	63
12/22/2023	Innovation Lab	345	Unknown	2700	Active	Passed		86	18	63
12/22/2023	Innovation Lab	333	Unknown	2692	Active	Passed		89	18	63
12/22/2023	Innovation Lab	345	Unknown	2699	Active	Passed		81	18	63
12/22/2023	Innovation Lab	345	Unknown	2698	Active	Passed		90	18	63
12/22/2023	Innovation Lab	341	Unknown	2697	Active	Passed		88	18	63
12/22/2023	Innovation Lab	315	Unknown	2687	Active	Passed		99	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
12/22/2023	Innovation Lab	341	Unknown	2696	Active	Passed		81	18	63
12/22/2023	Innovation Lab	321	Unknown	2691	Active	Passed		87	18	63
12/22/2023	Innovation Lab	341	Unknown	2694	Active	Passed		89	18	63
12/22/2023	Innovation Lab	341	Unknown	2695	Active	Passed		90	18	63
12/22/2023	Innovation Lab	223	Unknown	2702	Active	Passed		85	18	53
12/22/2023	Innovation Lab	231B	Unknown	2703	Active	Passed		90	18	63
12/22/2023	Innovation Lab	241	Unknown	2704	Active	Passed		89	18	63
12/22/2023	Innovation Lab	315	Unknown	2683	Active	Passed		110	18	63
12/22/2023	Innovation Lab	345	Unknown	2701	Active	Passed		83	18	63
12/22/2023	Innovation Lab	315	Unknown	2690	Active	Passed		107	18	63
12/22/2023	Innovation Lab	315	Unknown	2689	Active	Passed		104	18	63
3/28/2023	JOHNSON HALL	201C	Geological Sciences	788	Active	Failed		174	18	
9/20/2024	JOHNSON HALL	402 A	Quaternary Research Center	1936	Active	Passed		91	18	63
9/20/2024	JOHNSON HALL	122	Biology Program	1921	Active	Passed		102	18	62
9/20/2024	JOHNSON HALL	117	Earth , Space and Science	1920	Inactive	Failed		120	18	86
9/20/2024	JOHNSON HALL	039A	Earth , Space and Science	1919	Active	Passed		91	18	50
9/20/2024	JOHNSON HALL	303 B	Quaternary Research Center	1931	Active	Passed		120	18	62
9/20/2024	JOHNSON HALL	305 A	Quaternary Research Center	1933	Active	Passed		110	18	86
9/20/2024	JOHNSON HALL	221	Biology Program	1926	Active	Passed		97	18	62
9/20/2024	JOHNSON HALL	217	Biology Program	1925	Active	Passed		106	18	62
9/20/2024	JOHNSON HALL	422	Quaternary Research Center	1949	Active	Passed		112	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
9/20/2024	JOHNSON HALL	126	Biology Program	1922	Active	Passed		100	18	62
9/20/2024	JOHNSON HALL	402 A	Quaternary Research Center	1935	Active	Passed		114	18	63
9/20/2024	JOHNSON HALL	202 A	Biology Program	1923	Active	Passed		105	18	62
9/20/2024	JOHNSON HALL	422	Quaternary Research Center	1950	Active	Passed		141	18	62
9/20/2024	JOHNSON HALL	418	Quaternary Research Center	1948	Active	Passed		109	18	62
9/20/2024	JOHNSON HALL	417	Quaternary Research Center	1947	Active	Passed		115	18	50
9/20/2024	JOHNSON HALL	318	Quaternary Research Center	1934	Active	Passed		122	18	50
9/20/2024	JOHNSON HALL	403 B	Quaternary Research Center	1939	Active	Passed		93	18	86
9/20/2024	JOHNSON HALL	203 B	Biology Program	1924	Active	Passed		118	18	62
9/20/2024	JOHNSON HALL	303 B	Quaternary Research Center	1932	Active	Passed		118	18	62
9/20/2024	JOHNSON HALL	226	Earth , Space and Science	1927	Active	Passed		113	18	50
9/20/2024	JOHNSON HALL	302 A	Quaternary Research Center	1928	Active	Passed		109	18	62
9/20/2024	JOHNSON HALL	302 B	Quaternary Research Center	1929	Active	Passed		148	18	63
10/6/2023	KANE HALL	118A	Chemistry	790	Active	Passed		107	18	48
6/1/2023	KINCAID HALL	038	Biology Program	886	Active	Passed		104	26	36
2/2/2024	Life Sciences Building	212E	Biology Program	2624	Active	Passed		84	18	86
2/2/2024	Life Sciences Building	512A	Biology Program	2633	Active	Passed		86	18	86
2/2/2024	Life Sciences Building	412E	Biology Program	2632	Active	Passed		81	18	88
2/2/2024	Life Sciences Building	412D	Biology Program	2631	Active	Passed		77	18	86
2/2/2024	Life Sciences Building	412B	Biology Program	2630	Active	Passed		83	18	86
2/2/2024	Life Sciences Building	412A	Biology Program	2629	Active	Passed		76	18	86

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
2/2/2024	Life Sciences Building	312E	Biology Program	2628	Active	Passed		78	18	86
2/2/2024	Life Sciences Building	312D	Biology Program	2627	Active	Passed		88	18	86
2/2/2024	Life Sciences Building	113	Biology Program	2618	Active	Passed		88	18	38
2/2/2024	Life Sciences Building	312A	Unknown	2625	Active	Failed		119	18	86
2/2/2024	Life Sciences Building	113A	Biology Program	2615	Active	Passed		77	18	38
2/2/2024	Life Sciences Building	212D	Biology Program	2623	Active	Passed		83	18	886
2/2/2024	Life Sciences Building	212B	Biology Program	2622	Active	Passed		84	18	86
2/2/2024	Life Sciences Building	212A	Biology Program	2621	Active	Passed		75	18	86
2/2/2024	Life Sciences Building	119A	Biology Program	2614	Active	Passed		80	18	38
2/2/2024	Life Sciences Building	119	Biology Program	2613	Active	Passed		68	18	38
2/2/2024	Life Sciences Building	111A	Biology Program	2616	Active	Passed		78	18	38
2/2/2024	Life Sciences Building	111	Biology Program	2617	Active	Passed		85	18	38
2/2/2024	Life Sciences Building	312B	Biology Program	2626	Active	Passed		70	18	86
2/2/2024	Life Sciences Building	B145	Biology Program	2611	Active	Passed		83	16	52
2/2/2024	Life Sciences Building	512B	Biology Program	2634	Active	Passed		89	18	86
2/2/2024	Life Sciences Building	512D	Biology Program	2635	Active	Passed		80	18	86
2/2/2024	Life Sciences Building	105	Biology Program	2619	Active	Passed		61	18	38
2/2/2024	Life Sciences Building	105A	Biology Program	2620	Active	Passed		70	18	38
2/2/2024	Life Sciences Building	512E	Biology Program	2636	Active	Passed		83	18	86
2/2/2024	Life Sciences Building	B148	Biology Program	2610	Active	Passed		73	18	52
2/2/2024	Life Sciences Greenhouse	B161-GH	Biology Program	2612	Active	Passed		63	18	40

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
4/16/2024	Magnuson Health Sciences AA-wing	418	Surgery	1045	Inactive	Passed		0	0	53
4/16/2024	Magnuson Health Sciences AA-wing	108	Pathology	182	Active	Failed		65	18	60
4/16/2024	Magnuson Health Sciences AA-wing	108	Pathology	181	Active	Passed		83	18	60
4/16/2024	Magnuson Health Sciences AA-wing	214	Laboratory Medicine	191	Active	Passed		120	18	48
4/16/2024	Magnuson Health Sciences AA-wing	214	Laboratory Medicine	190	Active	Passed		113	18	48
4/16/2024	Magnuson Health Sciences AA-wing	412	Surgery	2219	Inactive	Failed		37	12	36
4/16/2024	Magnuson Health Sciences AA-wing	222	Laboratory Medicine	643	Active	Passed		108	18	48
4/28/2023	Magnuson Health Sciences BB-wing	1304	Pulmonary and Critical Care	607	Active	Passed		140	21	32
7/16/2024	Magnuson Health Sciences BB-wing	1544	Psychiatry and Behavioral Sciences	665	Inactive	Passed		93	18	60
7/16/2024	Magnuson Health Sciences BB-wing	1552	Psychiatry and Behavioral Sciences	666	Inactive	Passed		92	18	60
7/16/2024	Magnuson Health Sciences BB-wing	1009	Orthopaedics	647	Active	Passed		130	24	60
7/16/2024	Magnuson Health Sciences BB-wing	1556	Psychiatry and Behavioral Sciences	667	Inactive	Failed		193	12	38
7/16/2024	Magnuson Health Sciences BB-wing	1604	Neurology	668	Inactive	Passed		96	26	60
7/16/2024	Magnuson Health Sciences BB-wing	1032	Orthopaedics	648	Active	Passed		96	18	36
7/16/2024	Magnuson Health Sciences BB-wing	1312	Medicine	459	Active	Passed		116	18	60
7/16/2024	Magnuson Health Sciences BB-wing	1304	Pulmonary and Critical Care	458	Active	Passed		90	18	36
7/16/2024	Magnuson Health Sciences BB-wing	1369	Medicine	467	Active	Passed		89	28	36
7/16/2024	Magnuson Health Sciences BB-wing	1052	Orthopaedics	649	Active	Passed		129	18	60
7/16/2024	Magnuson Health Sciences BB-wing	1402	Medicine	933	Active	Passed		129	20	60
7/16/2024	Magnuson Health Sciences BB-wing	1502	Psychiatry and Behavioral Sciences	920	Inactive	Passed		134	29	60
7/16/2024	Magnuson Health Sciences BB-wing	1202	Medicine	651	Inactive	Failed		125	18	36

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
7/16/2024	Magnuson Health Sciences BB-wing	1416	Anesthesiology	661	Inactive	Failed		110	18	60
7/16/2024	Magnuson Health Sciences BB-wing	1369	Medicine	468	Active	Passed		91	18	60
7/16/2024	Magnuson Health Sciences BB-wing	1130	Urology	650	Active	Passed		123	18	60
7/17/2024	Magnuson Health Sciences BB-wing	632	Obstetrics and Gynecology	932	Inactive	Failed		38	18	38
7/17/2024	Magnuson Health Sciences BB-wing	628	Obstetrics and Gynecology	1105	Inactive	Failed		0	0	60
7/17/2024	Magnuson Health Sciences BB-wing	426	Surgery	628	Inactive	Failed		0	0	36
7/17/2024	Magnuson Health Sciences BB-wing	857	Neurology	2528	Active	Failed		73	18	63
7/17/2024	Magnuson Health Sciences BB-wing	826	Rehabilitation Medicine	1094	Inactive	Failed		16	18	64
7/17/2024	Magnuson Health Sciences BB-wing	531	Genetics	1101	Active	Passed		88	28	36
7/18/2024	Magnuson Health Sciences BB-wing	250A	Anatomic Pathology	2164	Active	Failed		75	18	50
7/30/2024	Magnuson Health Sciences BB-wing	030A	Radiation Oncology	894	Active	Passed		107	16	60
8/2/2024	Magnuson Health Sciences BB-wing	532	Metabolism, Endocrinology, and Nutrition, Medicine	1837	Inactive	Passed		0	0	40
8/2/2024	Magnuson Health Sciences BB-wing	532	Metabolism, Endocrinology, and Nutrition, Medicine	1838	Inactive	Failed		20	18	40
10/9/2024	Magnuson Health Sciences BB-wing	222	Pathology	1814	Active	Passed		97	18	40
11/4/2024	Magnuson Health Sciences BB-wing	612	Obstetrics and Gynecology	1103	Active	Failed		27	18	60
11/4/2024	Magnuson Health Sciences BB-wing	544	Medicine	653	Active	Failed		19	0	44
11/4/2024	Magnuson Health Sciences BB-wing	550	Metabolism, Endocrinology, and Nutrition, Medicine	1102	Active	Passed		0	0	60
10/7/2024	Magnuson Health Sciences B-wing	128	Oral Biology	634	Active	Passed		90	18	60
10/7/2024	Magnuson Health Sciences B-wing	149	Oral Biology	635	Active	Failed		114	18	51
10/7/2024	Magnuson Health Sciences B-wing	B529	Orthodontics	640	Active	Passed		150	31	41

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/7/2024	Magnuson Health Sciences B-wing	164	Restorative Dentistry	830	Active	Failed		128	18	41
10/8/2024	Magnuson Health Sciences B-wing	B122K	Environmental Health and Safety	1141	Active	Passed		103	24	48
10/14/2024	Magnuson Health Sciences C-wing	209L	Medicine	1020	Active	Passed		110	28	52
10/14/2024	Magnuson Health Sciences C-wing	405	Pathology	753	Inactive	Passed		0	24	41
10/14/2024	Magnuson Health Sciences C-wing	411	Pathology	1048	Active	Passed		130	18	38
10/14/2024	Magnuson Health Sciences C-wing	415	Pathology	2202	Active	Passed		96	18	38
10/14/2024	Magnuson Health Sciences C-wing	525	Pathology	754	Inactive	Passed		0	6	41
10/14/2024	Magnuson Health Sciences C-wing	526-B	Pathology	1759	Active	Passed		114	25	52
10/14/2024	Magnuson Health Sciences C-wing	526-B	Pathology	1758	Active	Passed		112	24	52
4/10/2024	Magnuson Health Sciences D-wing	408	Pharmacology	1799	Active	Passed		89	24	50
4/10/2024	Magnuson Health Sciences D-wing	430	Pharmacology	1798	Active	Passed		127	27	50
4/10/2024	Magnuson Health Sciences D-wing	430	Pharmacology	1801	Active	Failed		106	18	50
4/10/2024	Magnuson Health Sciences D-wing	408	Pharmacology	1800	Active	Passed		116	18	50
4/10/2024	Magnuson Health Sciences D-wing	218A	Medical Genetics	594	Active	Passed		104	18	60
4/10/2024	Magnuson Health Sciences D-wing	165B	Restorative Dentistry	1571	Active	Passed		123	18	38
4/10/2024	Magnuson Health Sciences D-wing	165A	Restorative Dentistry	1570	Active	Failed		71	18	98
4/10/2024	Magnuson Health Sciences D-wing	424	Pharmacology	1153	Active	Passed		99	28	48
4/11/2024	Magnuson Health Sciences D-wing	518	Pathology	1761	Active	Failed		151	18	52
4/11/2024	Magnuson Health Sciences D-wing	785A	Restorative Dentistry	598	Active	Passed		146	28	36
4/11/2024	Magnuson Health Sciences D-wing	782	Restorative Dentistry	611	Active	Passed		119	24	36
4/11/2024	Magnuson Health Sciences D-wing	759	Restorative Dentistry	1157	Active	Passed		126	27	36

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
4/11/2024	Magnuson Health Sciences D-wing	560	Periodontics	946	Active	Passed		119	20	34
4/11/2024	Magnuson Health Sciences D-wing	220	Periodontics	595	Active	Passed		140	20	56
4/11/2024	Magnuson Health Sciences D-wing	559	Periodontics	945	Active	Passed		144	27	36
4/11/2024	Magnuson Health Sciences D-wing	518	Pathology	1760	Active	Passed		148	18	52
4/11/2024	Magnuson Health Sciences D-wing	352	Dental Public Health Sciences	597	Active	Failed		140	18	35
4/11/2024	Magnuson Health Sciences D-wing	224	Oral Health Research	608	Active	Passed		94	18	38
4/11/2024	Magnuson Health Sciences D-wing	532	Pathology	934	Active	Passed		124	27	48
4/12/2024	Magnuson Health Sciences D-wing	254G	Unknown	2590	Active	Passed		59	18	50
4/12/2024	Magnuson Health Sciences D-wing	254G	Unknown	2591	Active	Passed		61	18	50
4/24/2024	Magnuson Health Sciences D-wing	514	Pathology	1768	Active	Passed		107	18	52
4/24/2024	Magnuson Health Sciences D-wing	529	Pathology	937	Active	Passed		111	28	48
7/26/2024	Magnuson Health Sciences D-wing	528	Pathology	936	Active	Passed		155	18	48
10/17/2024	Magnuson Health Sciences D-wing	426	Pharmacology	938	Active	Passed		1	1	48
4/8/2024	Magnuson Health Sciences E-wing	504	Pathology	1756	Active	Failed		160	18	52
4/8/2024	Magnuson Health Sciences E-wing	506	Pathology	1754	Active	Passed		131	18	52
4/8/2024	Magnuson Health Sciences E-wing	506	Pathology	1755	Active	Failed		157	18	52
4/8/2024	Magnuson Health Sciences E-wing	406	Pharmacology	939	Active	Passed		98	24	60
4/8/2024	Magnuson Health Sciences E-wing	410	Pharmacology	582	Active	Passed		90	18	48
4/8/2024	Magnuson Health Sciences E-wing	504	Pathology	1757	Active	Passed		121	23	52
4/9/2024	Magnuson Health Sciences E-wing	079A	Pathology	578	Active	Passed		115	24	48
4/9/2024	Magnuson Health Sciences E-wing	174	Environmental Health	591	Active	Passed		110	20	48

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
4/9/2024	Magnuson Health Sciences E-wing	168	Environmental Health	586	Active	Passed		149	18	48
4/9/2024	Magnuson Health Sciences E-wing	164B	Environmental Health	585	Active	Passed		111	20	48
4/9/2024	Magnuson Health Sciences E-wing	164	Environmental Health	584	Active	Failed		32	18	48
10/15/2024	Magnuson Health Sciences E-wing	426	Pharmacology	1572	Active	Passed		113	24	62
1/18/2024	Magnuson Health Sciences F-wing	212	Physiology and Biophysics	980	Active	Failed		6	18	50
1/18/2024	Magnuson Health Sciences F-wing	562	Environmental Health	314	Active	Passed		143	16	84
1/18/2024	Magnuson Health Sciences F-wing	553F	Environmental Health	312	Active	Passed		107	24	60
1/18/2024	Magnuson Health Sciences F-wing	553	Environmental Health	313	Active	Passed		115	18	60
1/18/2024	Magnuson Health Sciences F-wing	542	Environmental Health	310	Active	Passed		114	26	48
1/18/2024	Magnuson Health Sciences F-wing	542	Environmental Health	309	Active	Passed		91	28	48
1/18/2024	Magnuson Health Sciences F-wing	530	Biological Structure	2154	Active	Passed		79	18	60
1/18/2024	Magnuson Health Sciences F-wing	524	Biological Structure	2153	Active	Passed		96	18	60
1/18/2024	Magnuson Health Sciences F-wing	066	Pathobiology	176	Active	Passed		114	19	60
1/18/2024	Magnuson Health Sciences F-wing	047	Environmental Health	2203	Active	Passed		114	18	58
1/18/2024	Magnuson Health Sciences F-wing	042	Pathobiology	921	Active	Passed		93	18	60
1/18/2024	Magnuson Health Sciences F-wing	047	Pathobiology	1557	Active	Passed		89	27	50
1/22/2024	Magnuson Health Sciences F-wing	443	Environmental Health	193	Active	Failed		152	18	60
1/22/2024	Magnuson Health Sciences F-wing	454	Environmental Health	295	Active	Passed		100	18	60
1/22/2024	Magnuson Health Sciences F-wing	454	Environmental Health	296	Active	Failed		126	27	48
1/22/2024	Magnuson Health Sciences F-wing	466	Environmental Health	302	Active	Passed		119	26	48
1/22/2024	Magnuson Health Sciences F-wing	456	Environmental Health	299	Active	Failed		153	18	60

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
1/22/2024	Magnuson Health Sciences F-wing	457A	Environmental Health	298	Active	Passed		121	18	60
1/22/2024	Magnuson Health Sciences F-wing	458	Environmental Health	300	Active	Passed		102	24	48
1/22/2024	Magnuson Health Sciences F-wing	466	Environmental Health	301	Active	Passed		116	21	60
1/22/2024	Magnuson Health Sciences F-wing	451A	Environmental Health	294	Active	Passed		276	8	60
1/22/2024	Magnuson Health Sciences F-wing	410	Pharmacology	187	Active	Passed		99	18	50
1/22/2024	Magnuson Health Sciences F-wing	404	Pharmacology	188	Active	Passed		94	20	60
1/22/2024	Magnuson Health Sciences F-wing	442	Environmental Health	292	Active	Passed		109	18	80
1/22/2024	Magnuson Health Sciences F-wing	455	Environmental Health	297	Active	Passed		86	18	60
9/25/2024	Magnuson Health Sciences F-wing	F-562	Pharmacy	2705	Active	Passed		107	18	62
10/7/2024	Magnuson Health Sciences F-wing	428	Pharmacology	192	Active	Passed		97	28	60
10/7/2024	Magnuson Health Sciences F-wing	504	Biological Structure	303	Active	Passed		0	0	38
10/7/2024	Magnuson Health Sciences F-wing	511	Biological Structure	305	Active	Passed		112	24	60
10/7/2024	Magnuson Health Sciences F-wing	518	Biological Structure	2152	Active	Passed		113	18	60
10/7/2024	Magnuson Health Sciences F-wing	428	Pharmacology	186	Active	Passed		115	25	58
10/11/2024	Magnuson Health Sciences F-wing	510A	Biological Structure	304	Active	Passed		115	24	38
10/15/2024	Magnuson Health Sciences F-wing	502	Biological Structure	947	Inactive	Failed		103	18	38
10/2/2024	Magnuson Health Sciences G-wing	418	Physiology and Biophysics	983	Active	Failed		166	18	38
10/3/2024	Magnuson Health Sciences G-wing	524	Biological Structure	2155	Active	Passed		112	18	60
10/3/2024	Magnuson Health Sciences G-wing	406	Physiology and Biophysics	982	Active	Passed		105	24	38
10/3/2024	Magnuson Health Sciences G-wing	402	Physiology and Biophysics	981	Active	Passed		93	28	38
10/3/2024	Magnuson Health Sciences G-wing	320	Microbiology	978	Active	Passed		126	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/3/2024	Magnuson Health Sciences G-wing	219A	Physiology and Biophysics	572	Inactive	Passed		150	18	50
10/3/2024	Magnuson Health Sciences G-wing	310	Microbiology	1831	Active	Passed		89	18	48
10/3/2024	Magnuson Health Sciences G-wing	230	Physiology and Biophysics	977	Active	Passed		107	24	62
10/3/2024	Magnuson Health Sciences G-wing	412	Physiology and Biophysics	984	Active	Passed		104	23	38
10/3/2024	Magnuson Health Sciences G-wing	530	Biological Structure	2156	Active	Passed		99	18	60
9/6/2023	Magnuson Health Sciences H-wing	059	Medicinal Chemistry	1189	Active	Failed		112	18	63
8/29/2024	Magnuson Health Sciences H-wing	126	Immunology	1840	Active	Passed		0	18	52
10/16/2024	Magnuson Health Sciences H-wing	260	Pharmacy	1213	Active	Passed		143	18	51
10/16/2024	Magnuson Health Sciences H-wing	253	Pharmacy	1217	Active	Passed		107	18	51
10/16/2024	Magnuson Health Sciences H-wing	260	Pharmacy	1214	Active	Failed		137	18	51
10/16/2024	Magnuson Health Sciences H-wing	264	Pharmacy	1212	Active	Passed		132	18	51
10/16/2024	Magnuson Health Sciences H-wing	265	Pharmacy	1219	Active	Passed		104	18	63
10/16/2024	Magnuson Health Sciences H-wing	253	Pharmacy	1216	Active	Passed		130	18	51
10/16/2024	Magnuson Health Sciences H-wing	320	Physiology and Biophysics	2148	Active	Passed		88	18	72
10/16/2024	Magnuson Health Sciences H-wing	259	Pharmacy	1218	Active	Passed		104	18	63
10/16/2024	Magnuson Health Sciences H-wing	204	Physiology and Biophysics	2146	Active	Passed		100	18	72
10/16/2024	Magnuson Health Sciences H-wing	279A	Pharmacy	1220	Active	Failed		104	18	63
10/17/2024	Magnuson Health Sciences H-wing	168	Medicinal Chemistry	1209	Active	Failed		97	18	63
10/17/2024	Magnuson Health Sciences H-wing	132	Genetics	1839	Active	Failed		99	18	52
10/17/2024	Magnuson Health Sciences H-wing	159	Medicinal Chemistry	1203	Active	Passed		86	18	63
10/17/2024	Magnuson Health Sciences H-wing	168	Medicinal Chemistry	1208	Active	Failed		94	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/17/2024	Magnuson Health Sciences H-wing	179A	Medicinal Chemistry	1207	Active	Failed		77	18	63
10/17/2024	Magnuson Health Sciences H-wing	310J	Physiology and Biophysics	2147	Active	Failed		65	18	72
10/17/2024	Magnuson Health Sciences H-wing	179A	Medicinal Chemistry	1206	Active	Passed		95	18	63
10/21/2024	Magnuson Health Sciences H-wing	426	Physiology and Biophysics	2150	Active	Passed		109	18	60
10/21/2024	Magnuson Health Sciences H-wing	404	Physiology and Biophysics	2149	Active	Passed		98	18	72
10/21/2024	Magnuson Health Sciences H-wing	418	Physiology and Biophysics	1098	Active	Passed		95	18	50
10/21/2024	Magnuson Health Sciences H-wing	561	Immunology	1231	Active	Passed		127	18	63
10/21/2024	Magnuson Health Sciences H-wing	551	Immunology	1230	Active	Failed		233	18	63
10/21/2024	Magnuson Health Sciences H-wing	459	Immunology	1226	Active	Passed		117	18	63
10/21/2024	Magnuson Health Sciences H-wing	478	Immunology	1225	Active	Failed		108	18	63
10/21/2024	Magnuson Health Sciences H-wing	479	Immunology	1224	Active	Failed		123	18	63
10/21/2024	Magnuson Health Sciences H-wing	481B	Immunology	1227	Active	Failed		0	29	63
10/21/2024	Magnuson Health Sciences H-wing	502	Biological Structure	2157	Active	Failed		6	18	72
10/21/2024	Magnuson Health Sciences H-wing	578	Immunology	1229	Active	Failed		87	18	63
10/21/2024	Magnuson Health Sciences H-wing	579	Immunology	1228	Active	Passed		107	18	63
10/21/2024	Magnuson Health Sciences H-wing	514	Biological Structure	2159	Active	Passed		124	18	60
10/21/2024	Magnuson Health Sciences H-wing	506	Biological Structure	2158	Active	Passed		104	18	72
10/22/2024	Magnuson Health Sciences H-wing	068	Medicinal Chemistry	1199	Active	Failed		157	18	63
10/22/2024	Magnuson Health Sciences H-wing	068	Medicinal Chemistry	1198	Active	Passed		147	18	63
10/22/2024	Magnuson Health Sciences H-wing	068	Medicinal Chemistry	1200	Active	Passed		113	18	63
10/22/2024	Magnuson Health Sciences H-wing	068	Medicinal Chemistry	1201	Active	Passed		106	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/22/2024	Magnuson Health Sciences H-wing	073	Medicinal Chemistry	1169	Active	Failed		191	18	63
10/22/2024	Magnuson Health Sciences H-wing	072A	Medicinal Chemistry	1196	Active	Passed		111	18	63
10/22/2024	Magnuson Health Sciences H-wing	073	Medicinal Chemistry	1170	Active	Failed		117	18	63
10/22/2024	Magnuson Health Sciences H-wing	078	Medicinal Chemistry	1173	Active	Failed		163	18	63
10/22/2024	Magnuson Health Sciences H-wing	078	Medicinal Chemistry	1174	Active	Failed		75	18	63
10/22/2024	Magnuson Health Sciences H-wing	078	Medicinal Chemistry	1171	Active	Failed		128	18	63
10/22/2024	Magnuson Health Sciences H-wing	053	Medicinal Chemistry	1183	Active	Failed		184	18	63
10/22/2024	Magnuson Health Sciences H-wing	058	Medicinal Chemistry	1179	Active	Passed		115	18	63
10/22/2024	Magnuson Health Sciences H-wing	058	Medicinal Chemistry	1178	Active	Failed		94	18	63
10/22/2024	Magnuson Health Sciences H-wing	059	Medicinal Chemistry	1188	Active	Failed		117	18	63
10/22/2024	Magnuson Health Sciences H-wing	067	Medicinal Chemistry	1190	Active	Passed		101	18	63
10/22/2024	Magnuson Health Sciences H-wing	067	Medicinal Chemistry	1191	Active	Failed		161	18	63
10/22/2024	Magnuson Health Sciences H-wing	064	Medicinal Chemistry	1177	Active	Passed		129	18	63
10/22/2024	Magnuson Health Sciences H-wing	064	Medicinal Chemistry	1175	Active	Failed		189	18	63
10/22/2024	Magnuson Health Sciences H-wing	072A	Medicinal Chemistry	1197	Active	Failed		110	18	63
10/22/2024	Magnuson Health Sciences H-wing	064	Medicinal Chemistry	1176	Active	Passed		103	18	63
10/22/2024	Magnuson Health Sciences H-wing	078	Medicinal Chemistry	1172	Active	Passed		128	18	63
10/23/2024	Magnuson Health Sciences H-wing	353	Pharmacy	1222	Active	Passed		150	18	63
10/23/2024	Magnuson Health Sciences H-wing	428	Physiology and Biophysics	2151	Active	Passed		97	18	60
10/23/2024	Magnuson Health Sciences H-wing	353	Pharmacy	1223	Active	Passed		0	0	63
10/23/2024	Magnuson Health Sciences H-wing	268	Pharmacy	1221	Active	Failed		113	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/31/2024	Magnuson Health Sciences H-wing	330	Bioengineering	1914	Active	Failed		85	18	40
10/31/2024	Magnuson Health Sciences H-wing	330	Microbiology	1099	Active	Passed		84	18	36
10/31/2024	Magnuson Health Sciences H-wing	153	Medicinal Chemistry	1202	Active	Passed		133	18	38
6/13/2023	Magnuson Health Sciences I-wing	164A	Medicine	965	Active	Passed		94	24	60
6/13/2023	Magnuson Health Sciences I-wing	164G	Medicine	964	Active	Passed		128	24	60
11/8/2023	Magnuson Health Sciences I-wing	I329	Regional Primate Research Center	2680	Inactive	Passed		108	18	62
4/9/2024	Magnuson Health Sciences I-wing	332	Urology	545	Active	Passed		116	22	48
9/17/2024	Magnuson Health Sciences I-wing	312	Regional Primate Research Center	2107	Active	Passed		108	18	52
10/2/2024	Magnuson Health Sciences I-wing	607K	Howard Hughes Medical Institute	967	Active	Passed		122	24	60
10/2/2024	Magnuson Health Sciences I-wing	534-R	Biological Structure	554	Active	Failed		29	18	60
10/2/2024	Magnuson Health Sciences I-wing	516C	Biological Structure	2160	Active	Passed		90	18	72
10/2/2024	Magnuson Health Sciences I-wing	607J	Howard Hughes Medical Institute	970	Active	Passed		116	24	60
10/3/2024	Magnuson Health Sciences I-wing	093-E	Medicinal Chemistry	1256	Active	Passed		117	18	63
10/3/2024	Magnuson Health Sciences I-wing	607E	Howard Hughes Medical Institute	969	Active	Failed		46	24	60
10/3/2024	Magnuson Health Sciences I-wing	093A	Medicinal Chemistry	1255	Active	Passed		130	18	39
10/3/2024	Magnuson Health Sciences I-wing	204A	Medicine	899	Active	Passed		110	28	60
10/3/2024	Magnuson Health Sciences I-wing	534-Q	Biological Structure	555	Active	Passed		110	18	36
10/10/2024	Magnuson Health Sciences I-wing	097	Medicinal Chemistry	1254	Inactive	Passed		0	0	51
10/10/2024	Magnuson Health Sciences I-wing	104A	Allergy and Infectious Diseases	897	Active	Passed		150	18	60
10/14/2024	Magnuson Health Sciences I-wing	744	Regional Primate Research Center	1549	Active	Failed		49	24	60
10/14/2024	Magnuson Health Sciences I-wing	604E	Howard Hughes Medical Institute	973	Active	Passed		114	24	60

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/14/2024	Magnuson Health Sciences I-wing	604D	Howard Hughes Medical Institute	971	Active	Passed		104	18	60
10/14/2024	Magnuson Health Sciences I-wing	604K	Comparative Medicine	968	Active	Passed		104	26	60
10/14/2024	Magnuson Health Sciences I-wing	604J	Howard Hughes Medical Institute	966	Active	Passed		114	24	60
10/15/2024	Magnuson Health Sciences I-wing	004	Regional Primate Research Center	898	Active	Passed		130	17	60
10/16/2024	Magnuson Health Sciences I-wing	555	Regional Primate Research Center	557	Inactive	Failed		12	24	36
10/16/2024	Magnuson Health Sciences I-wing	089D	Regional Primate Research Center	1550	Active	Failed		77	24	50
11/1/2024	Magnuson Health Sciences J-wing	061J	Biochemistry	1151	Active	Failed		35	18	50
11/1/2024	Magnuson Health Sciences J-wing	112	Microbiology	2238	Active	Passed		68	18	50
11/1/2024	Magnuson Health Sciences J-wing	112	Microbiology	2237	Active	Passed		77	18	50
11/1/2024	Magnuson Health Sciences J-wing	112	Microbiology	2236	Active	Passed		73	18	50
11/1/2024	Magnuson Health Sciences J-wing	112	Microbiology	2235	Active	Passed		80	18	50
11/1/2024	Magnuson Health Sciences J-wing	136	Microbiology	2240	Active	Passed		84	18	50
11/1/2024	Magnuson Health Sciences J-wing	136	Microbiology	2241	Active	Passed		96	18	50
11/1/2024	Magnuson Health Sciences J-wing	136	Microbiology	2242	Active	Passed		78	18	50
11/1/2024	Magnuson Health Sciences J-wing	136	Microbiology	2239	Active	Passed		88	18	50
11/1/2024	Magnuson Health Sciences J-wing	631A	Howard Hughes Medical Institute	871	Active	Passed		144	18	60
11/1/2024	Magnuson Health Sciences J-wing	061C	Biochemistry	1152	Active	Passed		104	18	50
11/1/2024	Magnuson Health Sciences J-wing	631D	Howard Hughes Medical Institute	870	Active	Passed		132	18	60
3/13/2024	Magnuson Health Sciences K-wing	216	Genetics	1519	Active	Passed		115	17	63
3/13/2024	Magnuson Health Sciences K-wing	227	Neurology	1518	Active	Passed		101	17	63
3/13/2024	Magnuson Health Sciences K-wing	233	Neurology	1517	Active	Passed		87	17	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
3/13/2024	Magnuson Health Sciences K-wing	226	Genetics	1521	Active	Passed		85	17	63
3/13/2024	Magnuson Health Sciences K-wing	222	Genetics	1520	Active	Passed		83	17	63
3/14/2024	Magnuson Health Sciences K-wing	162	Genetics	1474	Active	Passed		119	17	51
3/14/2024	Magnuson Health Sciences K-wing	116	Microbiology	1480	Active	Passed		90	17	63
3/14/2024	Magnuson Health Sciences K-wing	160	Genetics	1475	Active	Failed		165	17	63
3/15/2024	Magnuson Health Sciences K-wing	262	Genetics	1524	Active	Passed		120	18	51
3/15/2024	Magnuson Health Sciences K-wing	257	Genetics	1528	Active	Failed		153	18	63
3/15/2024	Magnuson Health Sciences K-wing	244	Medicine	1522	Active	Passed		113	18	51
3/15/2024	Magnuson Health Sciences K-wing	260	Medicine	1525	Active	Passed		115	18	63
3/15/2024	Magnuson Health Sciences K-wing	254	Medicine	1523	Active	Passed		122	18	63
3/15/2024	Magnuson Health Sciences K-wing	263	Genetics	1527	Active	Passed		138	18	63
3/15/2024	Magnuson Health Sciences K-wing	265	Medicine	1526	Active	Passed		118	18	51
3/18/2024	Magnuson Health Sciences K-wing	307	Microbiology	2145	Active	Failed		151	18	72
3/18/2024	Magnuson Health Sciences K-wing	326	Genome Sciences	1506	Active	Passed		80	18	63
3/18/2024	Magnuson Health Sciences K-wing	322	Molecular Biotechnology	1507	Active	Passed		117	13	63
3/18/2024	Magnuson Health Sciences K-wing	316	Molecular Biotechnology	1508	Active	Passed		116	18	63
3/19/2024	Magnuson Health Sciences K-wing	065	Pathology	1467	Active	Passed		94	18	63
3/19/2024	Magnuson Health Sciences K-wing	081	Pathology	1466	Active	Passed		99	18	63
3/19/2024	Magnuson Health Sciences K-wing	058	Pathology	1462	Active	Passed		108	18	63
3/19/2024	Magnuson Health Sciences K-wing	056	Pathology	1461	Active	Passed		86	18	63
3/19/2024	Magnuson Health Sciences K-wing	085	Pathology	1465	Active	Passed		150	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
3/19/2024	Magnuson Health Sciences K-wing	088	Pathology	1464	Active	Failed		176	18	63
3/19/2024	Magnuson Health Sciences K-wing	084	Pathology	1463	Active	Passed		109	18	63
3/20/2024	Magnuson Health Sciences K-wing	165	Medicine	1471	Active	Failed		167	18	63
3/20/2024	Magnuson Health Sciences K-wing	161	Medicine	1470	Active	Failed		106	18	63
3/20/2024	Magnuson Health Sciences K-wing	167	Genetics	1473	Active	Failed		156	18	51
3/20/2024	Magnuson Health Sciences K-wing	107	Pathology	1804	Active	Failed		172	18	64
3/20/2024	Magnuson Health Sciences K-wing	030	Comparative Medicine	1459	Active	Passed		120	18	38
3/20/2024	Magnuson Health Sciences K-wing	017B	Comparative Medicine	2260	Active	Passed		88	18	63
3/20/2024	Magnuson Health Sciences K-wing	024B	Comparative Medicine	1458	Active	Passed		112	18	38
3/20/2024	Magnuson Health Sciences K-wing	127	Cardiology, Medicine	1468	Active	Passed		82	18	63
3/20/2024	Magnuson Health Sciences K-wing	126	Medicine	1478	Active	Passed		103	18	63
3/21/2024	Magnuson Health Sciences K-wing	007F*	Comparative Medicine	1456	Active	Passed		117	18	38
3/26/2024	Magnuson Health Sciences K-wing	354	Pharmacology	1516	Active	Passed		116	18	63
3/26/2024	Magnuson Health Sciences K-wing	359	Genome Sciences	1513	Active	Failed		182	18	63
3/26/2024	Magnuson Health Sciences K-wing	433	Surgery	1498	Active	Passed		111	18	63
3/26/2024	Magnuson Health Sciences K-wing	427	Microbiology	1497	Active	Passed		119	18	63
3/26/2024	Magnuson Health Sciences K-wing	363	Genome Sciences	1514	Active	Failed		154	18	63
3/26/2024	Magnuson Health Sciences K-wing	360	Genome Sciences	1515	Active	Passed		112	18	63
3/28/2024	Magnuson Health Sciences K-wing	460	Biological Structure	1504	Active	Passed		118	18	63
3/28/2024	Magnuson Health Sciences K-wing	522	Pharmacology	1484	Active	Passed		97	18	63
3/28/2024	Magnuson Health Sciences K-wing	426	Biochemistry	1494	Active	Passed		85	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
3/28/2024	Magnuson Health Sciences K-wing	460	Biological Structure	1503	Active	Passed		117	18	63
3/28/2024	Magnuson Health Sciences K-wing	460	Biological Structure	1502	Active	Passed		114	18	63
3/28/2024	Magnuson Health Sciences K-wing	460	Biological Structure	1505	Active	Passed		109	18	63
3/28/2024	Magnuson Health Sciences K-wing	464	Biological Structure	1501	Active	Passed		112	18	63
3/28/2024	Magnuson Health Sciences K-wing	516	Pharmacology	1483	Active	Passed		111	18	63
3/28/2024	Magnuson Health Sciences K-wing	455	Microbiology	1499	Active	Passed		142	18	63
3/28/2024	Magnuson Health Sciences K-wing	416	Biological Structure	1496	Active	Passed		112	18	63
3/29/2024	Magnuson Health Sciences K-wing	327	Genome Sciences	1509	Active	Passed		98	5	38
3/29/2024	Magnuson Health Sciences K-wing	555	Physiology and Biophysics	1492	Active	Passed		135	18	63
3/29/2024	Magnuson Health Sciences K-wing	327	Genome Sciences	1510	Active	Failed		75	18	63
3/29/2024	Magnuson Health Sciences K-wing	563	Physiology and Biophysics	1491	Active	Passed		141	18	63
3/29/2024	Magnuson Health Sciences K-wing	554	Pharmacology	1487	Active	Passed		125	18	63
3/29/2024	Magnuson Health Sciences K-wing	544	Pharmacology	1486	Active	Passed		97	18	51
3/29/2024	Magnuson Health Sciences K-wing	533	Pathology	1481	Active	Passed		100	18	63
3/29/2024	Magnuson Health Sciences K-wing	527	Pathology	1482	Active	Failed		94	18	63
3/29/2024	Magnuson Health Sciences K-wing	560	Pharmacology	1488	Active	Passed		100	18	63
3/29/2024	Magnuson Health Sciences K-wing	526	Pharmacology	1485	Active	Passed		101	18	63
4/3/2024	Magnuson Health Sciences K-wing	561	Physiology and Biophysics	1493	Active	Failed		230	18	51
4/3/2024	Magnuson Health Sciences K-wing	562	Pharmacology	1489	Active	Passed		140	18	51
5/6/2024	Magnuson Health Sciences K-wing	122	Medicine	1479	Active	Failed		88	18	63
7/18/2024	Magnuson Health Sciences K-wing	154	Genetics	1476	Active	Failed		112	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
7/26/2024	Magnuson Health Sciences K-wing	463	Microbiology	1500	Active	Passed		136	18	63
10/7/2024	Magnuson Health Sciences K-wing	155	Medicine	1469	Active	Passed		0	0	63
10/10/2024	Magnuson Health Sciences K-wing	565	Physiology and Biophysics	1490	Inactive	Passed		0	0	51
2/16/2023	Magnuson Health Sciences RR-wing	242*	Pediatrics	480	Active	Passed		101	18	
4/24/2024	Magnuson Health Sciences RR-wing	249	Pediatrics	483	Active	Passed		97	28	59
4/24/2024	Magnuson Health Sciences RR-wing	249	Pediatrics	484	Active	Passed		94	28	59
4/29/2024	Magnuson Health Sciences RR-wing	247	Pediatrics	481	Active	Failed		169	22	59
4/29/2024	Magnuson Health Sciences RR-wing	106	Gastroenterology	474	Active	Passed		96	24	59
4/29/2024	Magnuson Health Sciences RR-wing	012	Radiation Oncology	472	Active	Failed		192	23	54
4/29/2024	Magnuson Health Sciences RR-wing	108	Gastroenterology	476	Active	Passed		100	16	59
4/29/2024	Magnuson Health Sciences RR-wing	107	Gastroenterology	475	Active	Passed		95	18	59
5/13/2024	Magnuson Health Sciences RR-wing	637	Neurology	507	Active	Passed		126	24	60
5/13/2024	Magnuson Health Sciences RR-wing	436	Anesthesiology	494	Active	Passed		116	28	62
5/13/2024	Magnuson Health Sciences RR-wing	438	Anesthesiology	496	Active	Passed		122	28	62
5/13/2024	Magnuson Health Sciences RR-wing	815	Ophthalmology	516	Active	Passed		106	24	60
5/13/2024	Magnuson Health Sciences RR-wing	813	Ophthalmology	518	Active	Passed		108	24	60
5/13/2024	Magnuson Health Sciences RR-wing	715	Unknown	2644	Active	Passed		70	18	63
5/13/2024	Magnuson Health Sciences RR-wing	348	Pediatrics	493	Active	Passed		132	26	35
5/13/2024	Magnuson Health Sciences RR-wing	711	Neurology	1155	Active	Passed		115	18	50
5/13/2024	Magnuson Health Sciences RR-wing	610	Obstetrics and Gynecology	506	Active	Passed		100	24	60
5/13/2024	Magnuson Health Sciences RR-wing	505	Medicine	500	Active	Passed		108	18	64

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
5/13/2024	Magnuson Health Sciences RR-wing	606	Obstetrics and Gynecology	505	Active	Passed		112	18	62
5/13/2024	Magnuson Health Sciences RR-wing	540	Obstetrics and Gynecology	959	Active	Failed		156	24	50
5/13/2024	Magnuson Health Sciences RR-wing	535	Pediatrics	1734	Active	Passed		150	18	59
5/15/2024	Magnuson Health Sciences RR-wing	837	Ophthalmology	519	Active	Passed		128	18	59
5/15/2024	Magnuson Health Sciences RR-wing	309	Pediatrics	487	Active	Passed		126	18	59
5/15/2024	Magnuson Health Sciences RR-wing	335	Pediatrics	488	Inactive	Passed		94	18	59
5/15/2024	Magnuson Health Sciences RR-wing	337	Pediatrics	489	Active	Passed		147	23	59
5/15/2024	Magnuson Health Sciences RR-wing	344	Pediatrics	499	Active	Passed		104	22	59
5/15/2024	Magnuson Health Sciences RR-wing	410	Anesthesiology	215	Active	Passed		91	25	62
5/15/2024	Magnuson Health Sciences RR-wing	345	Pediatrics	492	Active	Passed		109	20	59
5/24/2024	Magnuson Health Sciences RR-wing	016	Radiation Oncology	473	Active	Passed		97	21	59
5/24/2024	Magnuson Health Sciences RR-wing	248	Pediatrics	482	Active	Passed		140	30	59
5/24/2024	Magnuson Health Sciences RR-wing	437	Pediatrics	495	Active	Passed		135	22	50
10/7/2024	Magnuson Health Sciences RR-wing	338	Pediatrics	490	Inactive	Passed		0	0	59
10/7/2024	Magnuson Health Sciences RR-wing	109	Gastroenterology	477	Active	Passed		118	20	60
10/7/2024	Magnuson Health Sciences RR-wing	747	Neurological Surgery	512	Active	Passed		0	0	48
10/7/2024	Magnuson Health Sciences RR-wing	739	Neurological Surgery	510	Active	Passed		122	24	50
10/8/2024	Magnuson Health Sciences RR-wing	751	Neurological Surgery	1563	Active	Passed		0	0	62
10/24/2024	Magnuson Health Sciences RR-wing	RR735	Unknown	2706	Inactive	Passed		112	18	62
2/8/2023	Magnuson Health Sciences T-wing	638	School of Nursing	1564	Active	Passed		146	18	38
2/8/2023	Magnuson Health Sciences T-wing	640	School of Nursing	954	Active	Passed		100	26	35

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
4/2/2024	Magnuson Health Sciences T-wing	293 S	Genome Sciences	1859	Active	Failed		65	18	60
4/2/2024	Magnuson Health Sciences T-wing	293 S	Laboratory Medicine	1070	Active	Failed		71	18	48
4/2/2024	Magnuson Health Sciences T-wing	378	Academic Support Services	2021	Active	Passed		110	19	82
4/2/2024	Magnuson Health Sciences T-wing	276	Academic Support Services	1096	Active	Passed		121	18	35
4/3/2024	Magnuson Health Sciences T-wing	163 A	Genetics	1074	Active	Passed		113	24	50
4/3/2024	Magnuson Health Sciences T-wing	163 K	Regional Primate Research Center	1073	Active	Passed		109	18	48
4/3/2024	Magnuson Health Sciences T-wing	163 K	Regional Primate Research Center	1072	Active	Passed		105	24	48
4/3/2024	Magnuson Health Sciences T-wing	163 N	Medicine	1071	Active	Passed		103	23	48
4/3/2024	Magnuson Health Sciences T-wing	565	Laboratory Medicine	958	Active	Passed		115	18	82
4/3/2024	Magnuson Health Sciences T-wing	577	Physiology and Biophysics	953	Active	Passed		107	18	82
4/3/2024	Magnuson Health Sciences T-wing	588A	Academic Support Services	1548	Active	Failed		30	24	36
4/5/2024	Magnuson Health Sciences T-wing	592	Academic Support Services	960	Active	Passed		106	24	72
4/5/2024	Magnuson Health Sciences T-wing	564	Environmental Health	1165	Active	Passed		92	18	82
4/5/2024	Magnuson Health Sciences T-wing	163 A	Genetics	1075	Active	Passed		86	18	48
4/5/2024	Magnuson Health Sciences T-wing	592	Academic Support Services	961	Active	Passed		116	24	72
4/5/2024	Magnuson Health Sciences T-wing	594	Academic Support Services	956	Active	Passed		118	20	35
5/31/2024	Magnuson Health Sciences T-wing	140L	Comparative Medicine	1616	Active	Passed		117	20	50
5/31/2024	Magnuson Health Sciences T-wing	274A	Radiation Safety	1095	Active	Passed		117	20	35
10/3/2024	Magnuson Health Sciences T-wing	576	Biochemistry	955	Inactive	Passed		0	0	82
7/12/2024	MARINE SCIENCES	273	School of Oceanography	776	Active	Passed		129	18	36
7/12/2024	MARINE SCIENCES	209	School of Oceanography	671	Active	Failed		151	18	60

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
7/12/2024	MARINE SCIENCES	217	School of Oceanography	773	Active	Passed		122	18	36
7/12/2024	MARINE SCIENCES	221	School of Oceanography	774	Active	Passed		119	18	36
7/12/2024	MARINE SCIENCES	207	School of Oceanography	670	Active	Passed		144	18	36
7/12/2024	MARINE SCIENCES	253	School of Oceanography	775	Active	Passed		137	20	36
7/12/2024	MARINE SCIENCES	209	School of Oceanography	672	Active	Passed		150	25	36
7/12/2024	MARINE SCIENCES	307	School of Oceanography	777	Active	Passed		117	18	36
7/12/2024	MARINE SCIENCES	319	School of Oceanography	701	Active	Passed		108	18	36
7/12/2024	MARINE SCIENCES	355	School of Oceanography	702	Active	Passed		82	18	48
7/12/2024	MARINE SCIENCES	357	School of Oceanography	703	Active	Passed		132	24	36
7/12/2024	MARINE SCIENCES	361	School of Oceanography	2201	Active	Passed		139	18	33
7/12/2024	MARINE SCIENCES	365	School of Oceanography	705	Active	Passed		116	18	36
7/12/2024	MARINE SCIENCES	371	School of Oceanography	706	Active	Passed		140	20	36
7/12/2024	MARINE SCIENCES	223	School of Oceanography	905	Active	Passed		108	18	36
7/12/2024	MARINE SCIENCES	215	School of Oceanography	876	Active	Passed		104	18	36
7/12/2024	MARINE SCIENCES	203	School of Oceanography	669	Active	Failed		166	18	48
6/12/2024	MARINE STUDIES	274	Institute for Food Science and Technology	783	Active	Passed		124	18	38
6/12/2024	MARINE STUDIES	170	Institute for Food Science and Technology	780	Active	Passed		144	20	50
6/12/2024	MARINE STUDIES	170	Institute for Food Science and Technology	779	Inactive	Failed		16	18	50
6/12/2024	MARINE STUDIES	176	Institute for Food Science and Technology	782	Active	Failed		23	18	50
6/12/2024	MARINE STUDIES	277	Institute for Food Science and Technology	1815	Active	Passed		146	22	52

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
6/12/2024	MARINE STUDIES	276	Institute for Food Science and Technology	786	Active	Failed		164	18	38
6/12/2024	MARINE STUDIES	276	Institute for Food Science and Technology	785	Active	Passed		143	20	38
6/12/2024	MARINE STUDIES	271B	Institute for Food Science and Technology	787	Active	Passed		124	18	50
6/12/2024	MARINE STUDIES	176	Institute for Food Science and Technology	781	Active	Passed		121	18	50
3/29/2024	McCarty Hall	B49	Housing and Food Services	2637	Active	Passed		101	18	63
1/26/2024	MECHANICAL ENGINEERING	B004	Mechanical Engineering	2544	Active	Passed		87	18	92
1/26/2024	MECHANICAL ENGINEERING	G 042	Mechanical Engineering	2459	Active	Passed		120	18	62
1/26/2024	MECHANICAL ENGINEERING	G 27	Mechanical Engineering	1729	Active	Passed		143	18	63
1/26/2024	MECHANICAL ENGINEERING	G 04	Mechanical Engineering	45	Active	Passed		143	18	38
4/10/2024	MERRILL HALL	10	Urban Horticulture Division	1887	Active	Passed		101	18	51
4/10/2024	MERRILL HALL	50	Urban Horticulture Division	1884	Active	Passed		112	18	51
4/10/2024	MERRILL HALL	51	Urban Horticulture Division	1885	Active	Passed		115	18	51
4/10/2024	MERRILL HALL	52	Urban Horticulture Division	1886	Active	Passed		106	18	51
9/20/2024	Milgard Hall	227	Unknown	2675	Active	Passed		77	18	36
9/20/2024	Milgard Hall	226	Unknown	2674	Active	Passed		84	18	36
9/20/2024	Milgard Hall	333	Unknown	2679	Active	Passed		80	18	36
9/20/2024	Milgard Hall	333	Unknown	2678	Active	Passed		74	18	64
9/20/2024	Milgard Hall	333	Unknown	2677	Active	Passed		76	18	64
9/20/2024	Milgard Hall	333	Unknown	2676	Active	Passed		79	18	36
6/27/2023	Molecular Engineering Building	G-021	Interdisciplinary	2312	Active	Passed		75	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
6/27/2023	Molecular Engineering Building	G-022	Interdisciplinary	2313	Active	Passed		78	18	63
6/27/2023	Molecular Engineering Building	G-042	Interdisciplinary	2310	Active	Passed		77	18	63
6/27/2023	Molecular Engineering Building	G-042	Interdisciplinary	2311	Active	Passed		73	18	63
6/28/2023	Molecular Engineering Building	140	Interdisciplinary	2298	Active	Passed		78	18	63
6/28/2023	Molecular Engineering Building	140-B	Interdisciplinary	2295	Active	Passed		82	18	87
6/28/2023	Molecular Engineering Building	140-B	Interdisciplinary	2294	Active	Passed		78	18	87
6/28/2023	Molecular Engineering Building	140	Interdisciplinary	2296	Active	Passed		83	18	63
6/28/2023	Molecular Engineering Building	240	Interdisciplinary	2299	Active	Passed		76	18	63
6/28/2023	Molecular Engineering Building	140	Interdisciplinary	2300	Active	Passed		86	18	63
6/28/2023	Molecular Engineering Building	140	Interdisciplinary	2301	Active	Passed		82	18	63
6/28/2023	Molecular Engineering Building	140	Interdisciplinary	2305	Active	Passed		78	18	63
6/28/2023	Molecular Engineering Building	140	Interdisciplinary	2306	Active	Passed		86	18	63
6/28/2023	Molecular Engineering Building	140	Interdisciplinary	2307	Active	Passed		86	18	63
6/28/2023	Molecular Engineering Building	140	Interdisciplinary	2278	Active	Passed		86	18	63
6/28/2023	Molecular Engineering Building	140	Interdisciplinary	2308	Active	Passed		83	18	63
6/28/2023	Molecular Engineering Building	140	Interdisciplinary	2302	Active	Passed		77	18	63
6/28/2023	Molecular Engineering Building	140	Interdisciplinary	2297	Active	Passed		84	18	63
7/13/2023	Molecular Engineering Building	340	Interdisciplinary	2276	Active	Passed		75	18	63
7/13/2023	Molecular Engineering Building	340	Interdisciplinary	2264	Active	Passed		67	18	63
7/13/2023	Molecular Engineering Building	340	Interdisciplinary	2269	Active	Passed		86	18	63
7/13/2023	Molecular Engineering Building	340	Interdisciplinary	2268	Active	Passed		81	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
7/13/2023	Molecular Engineering Building	340	Interdisciplinary	2267	Active	Passed		86	18	63
7/13/2023	Molecular Engineering Building	340	Interdisciplinary	2271	Active	Passed		78	18	63
7/13/2023	Molecular Engineering Building	340	Interdisciplinary	2270	Active	Passed		73	18	63
7/13/2023	Molecular Engineering Building	340	Interdisciplinary	2275	Active	Passed		82	18	63
7/13/2023	Molecular Engineering Building	340	Interdisciplinary	2273	Active	Passed		80	18	63
7/13/2023	Molecular Engineering Building	340	Interdisciplinary	2266	Active	Passed		81	18	63
7/13/2023	Molecular Engineering Building	340	Interdisciplinary	2265	Active	Passed		82	18	63
7/13/2023	Molecular Engineering Building	340	Interdisciplinary	2274	Active	Passed		80	18	63
7/13/2023	Molecular Engineering Building	340	Interdisciplinary	2272	Active	Passed		63	18	63
7/14/2023	Molecular Engineering Building	340	Interdisciplinary	2263	Active	Passed		83	18	63
7/14/2023	Molecular Engineering Building	240	Interdisciplinary	2289	Active	Passed		74	18	63
7/14/2023	Molecular Engineering Building	240	Interdisciplinary	2285	Active	Passed		83	18	63
7/14/2023	Molecular Engineering Building	240	Interdisciplinary	2288	Active	Passed		86	18	63
7/14/2023	Molecular Engineering Building	240	Interdisciplinary	2287	Active	Passed		82	18	63
7/14/2023	Molecular Engineering Building	240	Interdisciplinary	2292	Active	Passed		75	18	63
7/14/2023	Molecular Engineering Building	240	Interdisciplinary	2280	Active	Passed		82	18	63
7/14/2023	Molecular Engineering Building	240	Interdisciplinary	2290	Active	Passed		85	18	63
7/14/2023	Molecular Engineering Building	240	Interdisciplinary	2286	Active	Passed		81	18	63
7/14/2023	Molecular Engineering Building	240	Interdisciplinary	2284	Active	Passed		85	18	63
7/14/2023	Molecular Engineering Building	240	Interdisciplinary	2282	Active	Passed		86	18	63
7/14/2023	Molecular Engineering Building	240	Interdisciplinary	2283	Active	Passed		86	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
7/14/2023	Molecular Engineering Building	240	Interdisciplinary	2277	Active	Passed		75	18	63
7/14/2023	Molecular Engineering Building	240	Interdisciplinary	2279	Active	Passed		80	18	63
7/14/2023	Molecular Engineering Building	240	Interdisciplinary	2291	Active	Passed		85	18	63
8/24/2023	Molecular Engineering Building	240	Interdisciplinary	2281	Active	Passed		85	18	63
8/29/2023	Molecular Engineering Building	240	Interdisciplinary	2293	Active	Failed		43	18	63
8/29/2023	Molecular Engineering Building	140	Interdisciplinary	2303	Active	Failed		81	18	63
8/29/2023	Molecular Engineering Building	140	Interdisciplinary	2304	Active	Failed		51	18	63
9/27/2023	Molecular Engineering Building	G-042	Interdisciplinary	2309	Active	Failed		68	18	63
10/2/2024	Molecular Engineering Building	440	Interdisciplinary	2262	Active	Passed		84	18	63
4/20/2023	MORE HALL	320	Civil and Environmental Engineering	1745	Active	Passed		111	18	
7/18/2024	MORE HALL	320	Civil and Environmental Engineering	1744	Active	Passed		122	18	88
7/18/2024	MORE HALL	319	Civil and Environmental Engineering	1234	Active	Passed		84	22	60
7/18/2024	MORE HALL	319A	Civil and Environmental Engineering	1547	Active	Passed		102	24	84
7/18/2024	MORE HALL	319	Civil and Environmental Engineering	1233	Active	Passed		117	18	60
7/18/2024	MORE HALL	324	Civil and Environmental Engineering	1559	Active	Passed		147	24	64
7/18/2024	MORE HALL	324	Civil and Environmental Engineering	1561	Active	Passed		93	18	52
7/18/2024	MORE HALL	314	Civil and Environmental Engineering	1854	Active	Passed	20	132		38
7/18/2024	MORE HALL	034F	Civil and Environmental Engineering	915	Active	Passed		95	18	52
7/18/2024	MORE HALL	324	Civil and Environmental Engineering	1562	Active	Passed		123	22	88
7/18/2024	MORE HALL	324	Civil and Environmental Engineering	1560	Active	Passed		119	22	64
7/26/2024	MUELLER HALL	166B	Materials Science and Engineering	855	Active	Passed		91	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
7/26/2024	MUELLER HALL	165	Materials Science and Engineering	853	Active	Passed		100	18	50
7/26/2024	MUELLER HALL	183	Materials Science and Engineering	916	Active	Passed		94	18	50
7/26/2024	MUELLER HALL	187	Materials Science and Engineering	2663	Active	Passed		98	18	38
7/26/2024	MUELLER HALL	185	Materials Science and Engineering	857	Active	Passed		115	18	50
7/26/2024	MUELLER HALL	167	Materials Science and Engineering	848	Active	Passed		92	18	50
7/26/2024	MUELLER HALL	189	Materials Science and Engineering	856	Active	Passed		100	18	50
7/26/2024	MUELLER HALL	183	Materials Science and Engineering	844	Active	Passed		100	18	50
5/7/2024	Nanoengineering & Science Building	G-66	Nano Engineering & Sciences	2553	Active	Passed		101	18	63
5/7/2024	Nanoengineering & Science Building	G-67	Nano Engineering & Sciences	2552	Active	Passed		79	18	63
5/7/2024	Nanoengineering & Science Building	G-61	Nano Engineering & Sciences	2556	Active	Passed		69	18	63
5/7/2024	Nanoengineering & Science Building	G-64	Nano Engineering & Sciences	2558	Active	Passed		74	18	63
5/7/2024	Nanoengineering & Science Building	G-64	Nano Engineering & Sciences	2559	Active	Passed		82	18	63
5/7/2024	Nanoengineering & Science Building	G-66	Nano Engineering & Sciences	2554	Active	Passed		83	18	63
5/7/2024	Nanoengineering & Science Building	G-61	Nano Engineering & Sciences	2555	Active	Passed		68	18	63
5/7/2024	Nanoengineering & Science Building	G-91B	Nano Engineering & Sciences	2550	Active	Passed		73	18	63
5/7/2024	Nanoengineering & Science Building	G-91B	Nano Engineering & Sciences	2551	Active	Passed		80	18	63
5/7/2024	Nanoengineering & Science Building	G-62C	Nano Engineering & Sciences	2557	Active	Passed		81	18	63
5/8/2024	Nanoengineering & Science Building	280	Interdisciplinary	2664	Active	Passed		84	18	62
5/8/2024	Nanoengineering & Science Building	280	Nano Engineering & Sciences	2566	Active	Passed		89	18	63
5/8/2024	Nanoengineering & Science Building	280	Nano Engineering & Sciences	2565	Active	Passed		78	18	63
5/8/2024	Nanoengineering & Science Building	280	Nano Engineering & Sciences	2568	Active	Passed		77	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
5/8/2024	Nanoengineering & Science Building	280	Interdisciplinary	2665	Active	Passed		82	18	62
5/8/2024	Nanoengineering & Science Building	280	Nano Engineering & Sciences	2567	Active	Passed		76	18	63
5/8/2024	Nanoengineering & Science Building	280	Nano Engineering & Sciences	2564	Active	Passed		88	18	63
5/8/2024	Nanoengineering & Science Building	280	Nano Engineering & Sciences	2563	Active	Passed		63	18	63
5/10/2024	Nanoengineering & Science Building	380	Nano Engineering & Sciences	2572	Active	Passed		99	18	63
5/10/2024	Nanoengineering & Science Building	380	Nano Engineering & Sciences	2575	Active	Passed		79	18	63
5/10/2024	Nanoengineering & Science Building	380	Nano Engineering & Sciences	2576	Active	Passed		77	18	63
5/10/2024	Nanoengineering & Science Building	380	Nano Engineering & Sciences	2569	Active	Passed		77	18	63
5/10/2024	Nanoengineering & Science Building	380	Nano Engineering & Sciences	2570	Active	Passed		80	18	63
5/10/2024	Nanoengineering & Science Building	380	Nano Engineering & Sciences	2571	Active	Passed		74	18	63
5/10/2024	Nanoengineering & Science Building	380	Interdisciplinary	2666	Active	Passed		85	18	62
5/15/2024	Nanoengineering & Science Building	480A	Nano Engineering & Sciences	2577	Active	Passed		85	18	63
5/15/2024	Nanoengineering & Science Building	480A	Nano Engineering & Sciences	2578	Active	Passed		82	18	63
5/15/2024	Nanoengineering & Science Building	380	Nano Engineering & Sciences	2574	Active	Passed		83	18	63
5/15/2024	Nanoengineering & Science Building	380	Nano Engineering & Sciences	2573	Active	Passed		81	18	63
5/15/2024	Nanoengineering & Science Building	180	Nano Engineering & Sciences	2562	Active	Passed		81	18	63
5/15/2024	Nanoengineering & Science Building	180	Nano Engineering & Sciences	2561	Active	Passed		94	18	63
5/15/2024	Nanoengineering & Science Building	180	Nano Engineering & Sciences	2560	Active	Passed		80	18	86
5/15/2024	Nanoengineering & Science Building	480	Nano Engineering & Sciences	2579	Active	Passed		90	18	63
10/22/2024	NEW BURKE	203A	Unknown	2582	Active	Passed		86	18	51
10/22/2024	NEW BURKE	203P	Unknown	2585	Active	Passed		76	18	51

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/22/2024	NEW BURKE	307I	Unknown	2589	Active	Passed		70	18	63
10/22/2024	NEW BURKE	105A	Unknown	2581	Active	Passed		81	18	51
10/22/2024	NEW BURKE	203R	Unknown	2584	Active	Passed		100	18	51
10/22/2024	NEW BURKE	203O	Unknown	2586	Active	Passed		79	18	51
10/22/2024	NEW BURKE	307O	Unknown	2587	Active	Passed		82	18	63
10/22/2024	NEW BURKE	203C	Unknown	2583	Active	Passed		85	18	51
10/23/2024	NEW BURKE	307J	Biology Program	2588	Active	Passed		103	18	86
3/30/2023	OCEAN SCIENCES	444B	School of Oceanography	1704	Active	Failed		0	18	62
8/28/2024	OCEAN SCIENCES	540	School of Oceanography	1711	Active	Passed		114	18	62
8/28/2024	OCEAN SCIENCES	531	School of Oceanography	1718	Active	Passed		120	18	62
8/28/2024	OCEAN SCIENCES	531	School of Oceanography	1719	Active	Passed		116	18	62
8/28/2024	OCEAN SCIENCES	537	School of Oceanography	1721	Active	Passed		121	20	50
8/28/2024	OCEAN SCIENCES	543	School of Oceanography	1724	Active	Passed		111	18	88
8/28/2024	OCEAN SCIENCES	544	School of Oceanography	1713	Active	Passed		117	18	88
8/28/2024	OCEAN SCIENCES	544	School of Oceanography	1714	Active	Passed		114	18	62
8/28/2024	OCEAN SCIENCES	544	School of Oceanography	1712	Active	Passed		102	18	88
8/28/2024	OCEAN SCIENCES	532	School of Oceanography	1710	Active	Passed		108	18	88
8/29/2024	OCEAN SCIENCES	447	School of Oceanography	1709	Active	Passed		108	104	62
8/29/2024	OCEAN SCIENCES	344	School of Oceanography	1697	Active	Passed		113	18	62
8/29/2024	OCEAN SCIENCES	446	School of Oceanography	2580	Active	Passed		150	18	25
8/29/2024	OCEAN SCIENCES	440	School of Oceanography	1701	Active	Passed		171	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
8/29/2024	OCEAN SCIENCES	444	School of Oceanography	1703	Active	Passed		123	18	62
8/29/2024	OCEAN SCIENCES	440	School of Oceanography	1700	Active	Passed		110	18	62
8/29/2024	OCEAN SCIENCES	340	School of Oceanography	1696	Active	Passed		122	18	62
8/29/2024	OCEAN SCIENCES	435	School of Oceanography	1705	Active	Passed		130	18	62
8/29/2024	OCEAN SCIENCES	432	School of Oceanography	1699	Active	Passed		116	18	62
8/29/2024	OCEAN SCIENCES	346	School of Oceanography	1698	Active	Passed		117	18	62
8/29/2024	OCEAN SCIENCES	332	School of Oceanography	1694	Active	Passed		110	18	62
8/29/2024	OCEAN SCIENCES	336	School of Oceanography	1695	Active	Passed		127	18	62
8/29/2024	OCEAN SCIENCES	437	School of Oceanography	1706	Active	Passed		156	18	50
8/30/2024	OCEAN SCIENCES	547	School of Oceanography	1727	Active	Passed		115	18	88
8/30/2024	OCEAN SCIENCES	539	School of Oceanography	1722	Active	Passed		118	18	62
8/30/2024	OCEAN SCIENCES	546	School of Oceanography	1715	Active	Failed		320	18	62
8/30/2024	OCEAN SCIENCES	547	School of Oceanography	1726	Active	Failed		25	18	62
8/30/2024	OCEAN SCIENCES	543	School of Oceanography	1725	Active	Passed		111	18	62
8/30/2024	OCEAN SCIENCES	535	School of Oceanography	1720	Active	Passed		102	18	62
8/30/2024	OCEAN SCIENCES	527	School of Oceanography	1717	Active	Passed		111	18	62
8/30/2024	OCEAN SCIENCES	546	School of Oceanography	1716	Active	Failed		45	18	62
9/17/2024	OCEAN SCIENCES	437	School of Oceanography	1707	Active	Passed		135	18	50
6/21/2024	OCEAN TEACHING BUILDING	302	School of Oceanography	709	Active	Passed		123	24	36
6/21/2024	OCEAN TEACHING BUILDING	206	School of Oceanography	707	Active	Passed		89	18	36
6/21/2024	OCEAN TEACHING BUILDING	302	School of Oceanography	708	Active	Passed		133	24	36

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
6/21/2024	OCEAN TEACHING BUILDING	304	School of Oceanography	1126	Active	Passed		118	24	36
6/21/2024	OCEAN TEACHING BUILDING	305	School of Oceanography	1043	Active	Passed		119	22	48
6/21/2024	OCEAN TEACHING BUILDING	309	School of Oceanography	744	Active	Passed		138	18	36
6/21/2024	OCEAN TEACHING BUILDING	309	School of Oceanography	743	Active	Passed		110	18	36
6/21/2024	OCEAN TEACHING BUILDING	202	School of Oceanography	1119	Active	Passed		119	18	36
6/21/2024	OCEAN TEACHING BUILDING	306	School of Oceanography	1601	Active	Passed		110	18	38
9/28/2023	OCEANOGRAPHY BUILDING	306	Quaternary Research Center	1769	Inactive	Failed		0	18	62
9/28/2023	OCEANOGRAPHY BUILDING	316	School of Oceanography	739	Inactive	Failed		0	0	40
9/28/2023	OCEANOGRAPHY BUILDING	315	School of Oceanography	745	Inactive	Failed		0	0	60
9/28/2023	OCEANOGRAPHY BUILDING	216B	School of Oceanography	736	Inactive	Failed		0	0	60
6/15/2023	PHYSICS/ASTRON BAR	B050B	Physics	1247	Inactive	Passed		100	18	62
8/24/2023	PHYSICS/ASTRON BAR	B049	Physics	1246	Inactive	Passed		0	0	63
10/23/2024	PHYSICS/ASTRON BAR	B027	Physics	1237	Active	Passed		96	18	63
10/23/2024	PHYSICS/ASTRON BAR	B208B	Physics	1250	Active	Passed		104	18	38
10/23/2024	PHYSICS/ASTRON BAR	B228	Physics	1249	Active	Passed		107	18	62
10/23/2024	PHYSICS/ASTRON BAR	B308	Physics	1248	Active	Passed		116	30	62
10/23/2024	PHYSICS/ASTRON BAR	B079*	Biology Program	1259	Active	Passed		108	18	63
10/23/2024	PHYSICS/ASTRON BAR	B079*	Biology Program	1258	Active	Passed		115	18	63
10/23/2024	PHYSICS/ASTRON BAR	B090	Physics	1245	Active	Passed		112	18	86
10/23/2024	PHYSICS/ASTRON BAR	B092	Physics	1243	Active	Passed		90	18	63
10/23/2024	PHYSICS/ASTRON BAR	B021	Physics	1240	Active	Passed		110	20	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/23/2024	PHYSICS/ASTRON BAR	B034C	Physics	1585	Active	Passed		149	24	38
10/23/2024	PHYSICS/ASTRON BAR	B051	Biology Program	1257	Active	Passed		104	18	63
10/23/2024	PHYSICS/ASTRON BAR	B051	Physics	1238	Active	Passed		108	18	38
10/23/2024	PHYSICS/ASTRON BAR	B055A	Physics	1241	Active	Passed		114	18	62
10/23/2024	PHYSICS/ASTRON BAR	B059A	Physics	1244	Active	Passed		110	18	50
10/23/2024	PHYSICS/ASTRON BAR	B069	Physics	1242	Active	Passed		107	18	38
10/23/2024	PHYSICS/ASTRON BAR	B009	Physics	1236	Active	Passed		101	18	38
10/23/2024	PHYSICS/ASTRON BAR	B328B	Astronomy	1251	Active	Passed		120	30	38
9/28/2023	PORTAGE BAY BLDG	129	School of Fisheries	918	Active	Passed		0	18	52
9/28/2023	PORTAGE BAY BLDG	102K	Applied Physics Laboratory	729	Active	Passed		105	22	64
9/28/2023	PORTAGE BAY BLDG	114	Applied Physics Laboratory	734	Active	Passed		101	18	52
9/28/2023	PORTAGE BAY BLDG	102N	Applied Physics Laboratory	731	Active	Passed		93	20	52
9/28/2023	PORTAGE BAY BLDG	118A	Applied Physics Laboratory	900	Active	Failed		0	29	52
9/28/2023	PORTAGE BAY BLDG	M-12	School of Fisheries	677	Active	Passed		0	0	34
10/27/2023	RAITT HALL	128A	Nutritional Sciences	613	Inactive	Passed		0	0	32
10/27/2023	RAITT HALL	235	Epidemiology	615	Active	Passed		101	18	32
10/27/2023	RAITT HALL	125	Materials Science and Engineering	612	Inactive	Passed		0	0	84
7/26/2024	ROBERTS HALL	214	Materials Science and Engineering	993	Active	Passed		127	18	50
7/26/2024	ROBERTS HALL	216	Materials Science and Engineering	994	Active	Passed		136	18	50
7/26/2024	ROBERTS HALL	204	Materials Science and Engineering	992	Active	Passed		140	18	38
7/26/2024	ROBERTS HALL	134	Materials Science and Engineering	987	Active	Passed		166	18	38

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
7/26/2024	ROBERTS HALL	134	Materials Science and Engineering	988	Active	Passed		104	18	38
7/26/2024	ROBERTS HALL	138	Materials Science and Engineering	989	Active	Passed		97	18	38
7/26/2024	ROBERTS HALL	202	Materials Science and Engineering	991	Active	Passed		151	18	62
7/26/2024	ROBERTS HALL	221	Materials Science and Engineering	995	Active	Passed		137	18	38
7/26/2024	ROBERTS HALL	138	Materials Science and Engineering	990	Active	Passed		181	18	38
7/30/2024	ROBERTS HALL	129	Materials Science and Engineering	986	Active	Passed		155	18	38
3/12/2024	ROOSEVELT I	280	Environmental Health	1541	Active	Passed		133	18	60
3/12/2024	ROOSEVELT I	2312	Environmental Health	1904	Active	Passed		90	18	50
3/12/2024	ROOSEVELT I	260	Environmental Health	1542	Active	Passed		114	18	48
3/12/2024	ROOSEVELT I	260	Environmental Health	1543	Active	Passed		116	18	60
3/12/2024	ROOSEVELT I	260	Environmental Health	1544	Active	Passed		106	18	60
3/12/2024	ROOSEVELT I	194	Environmental Health	2023	Active	Passed		98	18	32
3/12/2024	ROOSEVELT I	194 A	Environmental Health	2670	Active	Passed		83	18	62
3/12/2024	ROOSEVELT I	2310	Environmental Health	1902	Active	Passed		83	18	50
3/12/2024	ROOSEVELT I	2295A	Environmental Health	1829	Active	Passed		115	18	48
3/12/2024	ROOSEVELT I	268	Environmental Health	1535	Active	Passed		114	18	60
3/12/2024	ROOSEVELT I	276	Environmental Health	1540	Active	Passed		107	18	60
3/12/2024	ROOSEVELT I	281	Environmental Health	1538	Active	Passed		101	18	60
3/12/2024	ROOSEVELT I	284	Environmental Health	1537	Active	Passed		111	18	60
3/12/2024	ROOSEVELT I	284	Environmental Health	1536	Active	Passed		114	18	60
3/12/2024	ROOSEVELT I	2295A	Environmental Health	2667	Active	Passed		108	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
3/12/2024	ROOSEVELT I	2299	Environmental Health	2668	Active	Passed		120	18	62
3/12/2024	ROOSEVELT I	2299A	Environmental Health	2669	Active	Passed		112	18	62
3/12/2024	ROOSEVELT I	2310	Environmental Health	1903	Active	Passed		78	18	50
3/12/2024	ROOSEVELT I	2297	Environmental Health	1828	Active	Passed		121	18	60
10/23/2024	ROOSEVELT I	260B	Environmental Health	1545	Active	Passed		126	18	60
10/23/2024	ROOSEVELT II	169	Metabolism, Endocrinology, and Nutrition, Medicine	1565	Active	Passed		126	18	38
10/23/2024	ROOSEVELT II	E184*	Unknown	2545	Active	Passed		86	18	50
10/21/2024	SLU 1 BROTMAN	336	Medicine	1870	Active	Passed		103	18	62
10/21/2024	SLU 1 BROTMAN	449	Medicine	1882	Active	Passed		108	18	62
10/21/2024	SLU 1 BROTMAN	317	Medicine	1874	Active	Passed		107	18	62
10/21/2024	SLU 1 BROTMAN	355	Medicine	1873	Active	Passed		99	18	62
10/21/2024	SLU 1 BROTMAN	357	Medicine	1875	Active	Passed		97	18	62
10/21/2024	SLU 1 BROTMAN	217	Medicine	1868	Active	Passed		112	18	62
10/21/2024	SLU 1 BROTMAN	424	Medicine	1878	Active	Passed		99	18	62
10/21/2024	SLU 1 BROTMAN	236	Medicine	1867	Active	Passed		108	18	62
10/21/2024	SLU 1 BROTMAN	325	Medicine	1871	Active	Passed		92	18	62
10/21/2024	SLU 1 BROTMAN	431	Medicine	1877	Active	Passed		105	18	62
10/21/2024	SLU 1 BROTMAN	417	Medicine	1879	Active	Passed		97	18	62
10/21/2024	SLU 1 BROTMAN	348	Medicine	1876	Active	Passed		110	18	62
10/21/2024	SLU 1 BROTMAN	436	Medicine	1883	Active	Passed		105	18	62
10/21/2024	SLU 1 BROTMAN	441	Medicine	1880	Active	Failed		96	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/21/2024	SLU 1 BROTMAN	341	Medicine	1872	Active	Passed		97	18	62
10/21/2024	SLU 1 BROTMAN	455	Medicine	1881	Active	Passed		117	18	62
10/21/2024	SLU 1 BROTMAN	118	Medicine	1863	Active	Passed		110	18	62
10/21/2024	SLU 1 BROTMAN	255	Medicine	1864	Active	Passed		115	18	62
10/21/2024	SLU 1 BROTMAN	331	Medicine	1869	Active	Passed		106	18	62
10/21/2024	SLU 1 BROTMAN	241	Medicine	1866	Active	Failed		101	18	62
10/21/2024	SLU 1 BROTMAN	151	Medicine	1862	Active	Passed		95	18	62
10/21/2024	SLU 1 BROTMAN	155	Medicine	1860	Active	Passed		105	18	62
10/21/2024	SLU 1 BROTMAN	141	Medicine	1861	Active	Passed		100	18	62
10/21/2024	SLU 1 BROTMAN	248	Medicine	1865	Active	Passed		105	18	62
10/23/2024	SLU 2 Lab North	528	Stem Cell Research	2108	Active	Passed		95	18	62
10/23/2024	SLU 2 Lab North	328	Department of Medicine	2123	Active	Passed		95	18	62
10/23/2024	SLU 2 Lab North	102A	Department of Medicine	2139	Active	Passed		84	18	38
10/23/2024	SLU 2 Lab North	125	Nuclear Medicine	2136	Active	Passed		96	18	62
10/23/2024	SLU 2 Lab North	235	Department of Medicine	2125	Active	Passed		111	18	62
10/23/2024	SLU 2 Lab North	117	Department of Medicine	2137	Active	Passed		100	18	62
10/23/2024	SLU 2 Lab North	N328	School of Medicine	2640	Active	Passed		85	18	51
10/23/2024	SLU 2 Lab North	318	Department of Medicine	2124	Active	Passed		111	18	62
10/23/2024	SLU 2 Lab North	217	Department of Medicine	2127	Active	Passed		99	18	62
10/23/2024	SLU 2 Lab North	418	Stem Cell Research	2117	Active	Passed		98	18	62
10/23/2024	SLU 2 Lab North	512	Stem Cell Research	2109	Active	Passed		95	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/30/2024	SLU 2 Lab North	428	Stem Cell Research	2118	Active	Failed		105	18	62
10/30/2024	SLU 2 Lab North	227	Pharmacology	2126	Active	Passed		94	18	62
1/22/2024	SLU 2 Lab South	522	Pharmacology	2111	Active	Passed		109	18	62
10/23/2024	SLU 2 Lab South	586	Biochemistry	2142	Active	Passed		112	18	48
10/23/2024	SLU 2 Lab South	586	Biochemistry	2112	Active	Passed		78	18	62
10/23/2024	SLU 2 Lab South	509	Pharmacology	2140	Active	Passed		109	18	38
10/23/2024	SLU 2 Lab South	122	Diabetesand Obesity Center for Excellence	2133	Active	Passed		109	18	62
10/23/2024	SLU 2 Lab South	185	Diabetes and Obesity Center for Excellence	2134	Active	Passed		115	18	62
10/23/2024	SLU 2 Lab South	185	Bioengineering	2184	Active	Passed		101	18	48
10/23/2024	SLU 2 Lab South	163	Diabetes and Obesity Center for Excellence	2135	Active	Failed		121	18	62
10/23/2024	SLU 2 Lab South	144	Diabetesand Obesity Center for Excellence	2132	Active	Passed		94	18	62
10/23/2024	SLU 2 Lab South	263	Diabetes and Obesity Center for Excellence	2131	Active	Passed		96	18	62
10/23/2024	SLU 2 Lab South	222	Diabetes and Obesity Center for Excellence	2129	Active	Passed		93	18	62
10/23/2024	SLU 2 Lab South	363	Lung Biology	2122	Active	Passed		111	18	62
10/23/2024	SLU 2 Lab South	386	Lung Biology	2121	Active	Passed		96	18	62
10/23/2024	SLU 2 Lab South	422	Biochemistry	2143	Active	Passed		100	18	48
10/23/2024	SLU 2 Lab South	344	Lung Biology	2119	Active	Passed		105	18	62
10/23/2024	SLU 2 Lab South	286	Diabetes and Obesity Center for Excellence	2130	Active	Passed		106	18	62
10/23/2024	SLU 2 Lab South	422	Stem Cell Research	2115	Active	Passed		105	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/23/2024	SLU 2 Lab South	444	Stem Cell Research	2116	Active	Passed		102	18	62
10/23/2024	SLU 2 Lab South	544	Biological Structure	2110	Active	Failed		105	18	62
10/23/2024	SLU 2 Lab South	463	Lung Biology	2113	Active	Passed		109	18	62
10/23/2024	SLU 2 Lab South	486	Metabolism, Endocrinology, and Nutrition, Medicine	2144	Active	Passed		112	18	48
10/23/2024	SLU 2 Lab South	486	Metabolism, Endocrinology, and Nutrition, Medicine	2114	Active	Passed		114	18	62
10/23/2024	SLU 2 Lab South	322	Lung Biology	2120	Active	Passed		110	18	62
10/23/2024	SLU 2 Lab South	522	Pharmacology	2141	Active	Passed		91	18	48
10/23/2024	SLU 2 Lab South	244	Diabetes and Obesity Center for Excellence	2128	Active	Passed		91	18	62
11/3/2023	SLU3 PHASE 3.1	P125	Medicine	2452	Active	Passed		60	18	52
10/25/2024	SLU3 PHASE 3.1	E342	Immunology	2436	Active	Passed		92	18	63
10/25/2024	SLU3 PHASE 3.1	E128	School of Medicine	2449	Active	Passed		126	18	63
10/25/2024	SLU3 PHASE 3.1	E128	School of Medicine	2450	Active	Passed		101	18	48
10/25/2024	SLU3 PHASE 3.1	E352	Immunology	2435	Active	Passed		90	18	63
10/25/2024	SLU3 PHASE 3.1	E324	Immunology	2437	Active	Passed		86	18	63
10/25/2024	SLU3 PHASE 3.1	E324	School of Medicine	2438	Active	Passed		104	18	72
10/25/2024	SLU3 PHASE 3.1	E272	School of Medicine	2446	Active	Passed		87	18	72
10/25/2024	SLU3 PHASE 3.1	E154A	School of Medicine	2448	Active	Passed		82	18	72
10/25/2024	SLU3 PHASE 3.1	E254	School of Medicine	2444	Active	Passed		91	18	72
10/25/2024	SLU3 PHASE 3.1	E254	Ophthalmology	2443	Active	Passed		72	18	63
10/25/2024	SLU3 PHASE 3.1	E242	School of Medicine	2441	Active	Passed		106	18	72

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/25/2024	SLU3 PHASE 3.1	E242	School of Medicine	2442	Active	Passed		82	18	72
10/25/2024	SLU3 PHASE 3.1	E146	School of Medicine	2451	Active	Passed		79	18	48
10/25/2024	SLU3 PHASE 3.1	E224	School of Medicine	2439	Active	Passed		93	18	72
10/25/2024	SLU3 PHASE 3.1	E224	Ophthalmology	2440	Active	Passed		74	18	63
10/25/2024	SLU3 PHASE 3.1	E272	School of Medicine	2445	Active	Passed		87	18	72
10/25/2024	SLU3 PHASE 3.1	E372	Immunology	2434	Active	Passed		95	18	63
10/28/2024	SLU3 PHASE 3.1	E524	Department of Medicine	2425	Active	Passed		85	18	63
10/28/2024	SLU3 PHASE 3.1	E472	Immunology	2428	Active	Passed		90	18	63
10/28/2024	SLU3 PHASE 3.1	E472	Immunology	2427	Active	Passed		103	18	63
10/28/2024	SLU3 PHASE 3.1	E454	Immunology	2430	Active	Passed		84	18	63
10/28/2024	SLU3 PHASE 3.1	E454	School of Medicine	2429	Active	Passed		88	18	72
10/28/2024	SLU3 PHASE 3.1	E442	Immunology	2432	Active	Passed		83	18	63
10/28/2024	SLU3 PHASE 3.1	E422	Immunology	2433	Active	Passed		87	18	63
10/28/2024	SLU3 PHASE 3.1	E542	Medicine	2424	Active	Passed		87	18	63
10/28/2024	SLU3 PHASE 3.1	E542	Medicine	2423	Active	Passed		92	18	63
10/28/2024	SLU3 PHASE 3.1	E442	Immunology	2431	Active	Passed		88	18	63
10/28/2024	SLU3 PHASE 3.1	E554	Immunology	2422	Active	Failed		89	18	63
10/28/2024	SLU3 PHASE 3.1	E572	Immunology	2419	Active	Passed		87	18	63
10/28/2024	SLU3 PHASE 3.1	E572	Immunology	2420	Active	Failed		88	18	63
10/28/2024	SLU3 PHASE 3.1	E624	School of Medicine	2417	Active	Passed		88	18	72
10/28/2024	SLU3 PHASE 3.1	E642	School of Medicine	2416	Active	Passed		86	18	72

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/28/2024	SLU3 PHASE 3.1	E654	School of Medicine	2418	Active	Passed		88	18	72
10/28/2024	SLU3 PHASE 3.1	E654	School of Medicine	2415	Active	Failed		84	18	72
10/28/2024	SLU3 PHASE 3.1	E524	School of Medicine	2426	Active	Passed		88	18	72
10/28/2024	SLU3 PHASE 3.1	E554	Immunology	2421	Active	Passed		101	18	63
10/30/2024	SLU3 PHASE 3.1	E282	School of Medicine	2447	Active	Passed		103	18	48
10/30/2024	SLU3 PHASE 3.1	E772	Immunology	2453	Active	Passed		110	18	63
10/28/2024	SLU-3.2	F432	School of Medicine	2593	Active	Failed		118	17	63
10/28/2024	SLU-3.2	F532	School of Medicine	2597	Active	Passed		93	17	63
10/28/2024	SLU-3.2	F522	School of Medicine	2596	Active	Passed		118	17	63
10/28/2024	SLU-3.2	F462	School of Medicine	2595	Active	Passed		123	17	63
10/28/2024	SLU-3.2	F452	School of Medicine	2594	Active	Passed		115	17	63
10/28/2024	SLU-3.2	F552	School of Medicine	2598	Active	Passed		142	17	63
10/28/2024	SLU-3.2	F422	School of Medicine	2592	Active	Passed		104	18	63
10/30/2024	SLU-3.2	F652	School of Medicine	2601	Active	Passed		127	17	63
10/30/2024	SLU-3.2	F762	School of Medicine	2607	Active	Passed		102	18	63
10/30/2024	SLU-3.2	F732	School of Medicine	2605	Active	Passed		116	17	63
10/30/2024	SLU-3.2	F622	School of Medicine	2600	Active	Passed		125	17	63
10/30/2024	SLU-3.2	F722	School of Medicine	2604	Active	Passed		135	18	63
10/30/2024	SLU-3.2	F612	School of Medicine	2599	Active	Passed		113	17	63
10/30/2024	SLU-3.2	F752	School of Medicine	2606	Active	Passed		113	17	63
10/30/2024	SLU-3.2	F654	Unknown	2602	Active	Passed		119	17	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/30/2024	SLU-3.2	F662	School of Medicine	2603	Active	Passed		125	17	63
10/30/2024	SLU-3.2	F634	School of Medicine	2608	Active	Passed		115	18	63
10/30/2024	SLU-3.2	F862	School of Medicine	2647	Active	Passed		93	18	64
10/30/2024	SLU-3.2	F822	School of Medicine	2645	Active	Passed		115	18	64
10/30/2024	SLU-3.2	F852	School of Medicine	2646	Active	Passed		101	18	64
10/6/2023	SUZZALLO LIBRARY	560C	Unknown	2543	Active	Failed		87	18	68
9/18/2024	Tacoma Paper & Stationary	208	Unknown	2661	Active	Passed		117	18	58
9/18/2024	Tacoma Paper & Stationary	209	Unknown	2662	Active	Passed		108	18	44
9/18/2024	Tacoma Paper & Stationary	309	Unknown	2659	Active	Passed		110	18	42
9/18/2024	Tacoma Paper & Stationary	308	Unknown	2660	Active	Passed		115	18	58
9/18/2024	Tacoma Science Bldg	SCI_311	Science	1793	Active	Passed		144	18	62
9/18/2024	Tacoma Science Bldg	SCI_315	Science	1797	Active	Passed		118	18	48
9/18/2024	Tacoma Science Bldg	SCI_311	Science	1790	Active	Passed		90	18	62
9/18/2024	Tacoma Science Bldg	SCI_315	Science	1796	Active	Passed		109	18	62
9/18/2024	Tacoma Science Bldg	SCI_311	Science	1794	Active	Passed		106	18	62
9/18/2024	Tacoma Science Bldg	SCI_311	Science	1792	Active	Passed		113	18	62
9/18/2024	Tacoma Science Bldg	SCI_311	Science	1791	Active	Passed		128	18	62
9/18/2024	Tacoma Science Bldg	SCI309	Unknown	2658	Active	Passed		116	18	38
9/18/2024	Tacoma Science Bldg	SCI309	Unknown	2657	Active	Passed		90	18	87
9/18/2024	Tacoma Science Bldg	SCI309	Unknown	2655	Active	Passed		100	18	87
9/18/2024	Tacoma Science Bldg	SCI309	Unknown	2654	Active	Passed		108	18	87

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
9/18/2024	Tacoma Science Bldg	SCI309	Unknown	2653	Active	Passed		112	18	87
9/18/2024	Tacoma Science Bldg	SCI309	Unknown	2652	Active	Passed		117	18	87
9/18/2024	Tacoma Science Bldg	SCI309	Unknown	2656	Active	Passed		110	18	87
9/18/2024	Tacoma Science Bldg	SCI_311	Science	1795	Active	Passed		127	18	62
9/19/2024	Tacoma Science Bldg	SCI_317	Geological Sciences	2210	Active	Passed		73	18	62
9/19/2024	Tacoma Science Bldg	SCI_304	Science	1781	Active	Passed		122	18	48
9/19/2024	Tacoma Science Bldg	SCI_310	Science	1783	Active	Passed		104	18	48
9/19/2024	Tacoma Science Bldg	SCI_310	Science	1782	Active	Passed		119	18	48
9/19/2024	Tacoma Science Bldg	SCI_312	Science	1785	Active	Passed		116	18	48
9/19/2024	Tacoma Science Bldg	SCI_312	Science	1784	Active	Passed		117	18	48
9/19/2024	Tacoma Science Bldg	SCI_336	Science	1788	Active	Passed		139	18	48
9/19/2024	Tacoma Science Bldg	SCI_334	Science	1789	Active	Passed		120	18	48
9/19/2024	Tacoma Science Bldg	SCI_317	Geological Sciences	2206	Active	Passed		80	18	62
9/19/2024	Tacoma Science Bldg	SCI_317	Geological Sciences	2211	Active	Passed		72	18	62
9/19/2024	Tacoma Science Bldg	SCI_317	Geological Sciences	2209	Active	Passed		69	18	62
9/19/2024	Tacoma Science Bldg	SCI_304	Science	1780	Active	Passed		120	18	48
9/19/2024	Tacoma Science Bldg	SCI_317	Geological Sciences	2208	Active	Passed		81	18	62
9/19/2024	Tacoma Science Bldg	SCI_207*	Geological Sciences	2205	Active	Passed		118	18	62
9/19/2024	Tacoma Science Bldg	SCI_317	Geological Sciences	2207	Active	Passed		80	18	62
9/19/2024	Tacoma Science Bldg	SCI_211	Science	1778	Active	Passed		132	18	62
9/19/2024	Tacoma Science Bldg	SCI_137	Geological Sciences	2204	Active	Passed		134	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
9/19/2024	Tacoma Science Bldg	SCI_236	Science	1786	Active	Failed		74	18	48
9/19/2024	Tacoma Science Bldg	SCI_236	Science	1773	Active	Passed		133	18	48
9/19/2024	Tacoma Science Bldg	SCI_234	Science	1774	Active	Passed		114	18	48
9/19/2024	Tacoma Science Bldg	SCI_234	Science	1775	Active	Passed		123	18	48
9/19/2024	Tacoma Science Bldg	SCI_217	Science	1776	Active	Passed		122	18	62
9/19/2024	Tacoma Science Bldg	SCI_215A	Science	1777	Active	Passed		133	18	62
9/19/2024	Tacoma Science Bldg	SCI_302	Science	1779	Active	Passed		120	18	48
2/28/2024	U W MED CTR/NW	NW 142D	Radiation Oncology	274	Active	Passed		121	30	40
7/30/2024	U W MED CTR/NW	NW 275A	Laboratory Medicine	291	Active	Passed		128	28	60
8/21/2024	U W MED CTR/NW	NW 147B	Radiation Oncology	276	Active	Passed		89	31	50
10/9/2024	U W MED CTR/NW	NW 053	Radiology	1017	Active	Failed		161	23	58
10/9/2024	U W MED CTR/NW	NW 176	Laboratory Medicine	277	Active	Passed		102	22	88
10/9/2024	U W MED CTR/NW	NW 047	Radiology	1010	Active	Passed		116	20	50
10/9/2024	U W MED CTR/NW	NW225	Laboratory Medicine	2639	Active	Passed		106	18	64
10/9/2024	U W MED CTR/NW	NW 050	Radiology	1728	Active	Passed		129	21	38
10/9/2024	U W MED CTR/NW	NW220	Laboratory Medicine	2542	Active	Passed		86	18	63
10/9/2024	U W MED CTR/NW	NW 053	Radiology	1016	Active	Passed		110	28	38
10/9/2024	U W MED CTR/NW	NW 049	Radiology	1012	Active	Passed		84	27	50
10/9/2024	U W MED CTR/NW	NW 053	Radiology	1014	Active	Passed		114	26	38
10/9/2024	U W MED CTR/NW	NW 125F	Pathology	273	Active	Failed		77	27	64
10/9/2024	U W MED CTR/NW	NW 053	Radiology	1013	Active	Passed		136	24	38

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/9/2024	U W MED CTR/NW	NW 177	Laboratory Medicine	1736	Active	Passed		97	18	50
10/9/2024	U W MED CTR/NW	NW 225	Laboratory Medicine	287	Active	Passed		100	18	60
10/9/2024	U W MED CTR/NW	NW 049	Radiology	1011	Active	Passed		145	27	86
10/17/2024	U W MED CTR/NW	NW 145	Laboratory Medicine	275	Active	Passed		116	29	64
5/30/2024	UWMC NW/A	A256	Laboratory Medicine	2648	Active	Passed		168	21	44
6/27/2024	Vandergraaff Accelerator	166	Physics	1590	Active	Passed		150	9	59
6/27/2024	Vandergraaff Accelerator	162	Physics	816	Active	Passed		106	22	60
6/27/2024	Vandergraaff Accelerator	165	Physics	1084	Active	Failed		11	18	222
6/27/2024	Vandergraaff Accelerator	166	Physics	817	Active	Passed		91	18	60
6/27/2024	Vandergraaff Accelerator	162	Physics	815	Active	Failed		47	18	60
2/6/2024	WH FOEGE BIOENG	N415A	Bioengineering	1969	Active	Passed		108	18	52
2/6/2024	WH FOEGE BIOENG	N561	Bioengineering	1952	Active	Passed		118	18	52
2/6/2024	WH FOEGE BIOENG	N415A	Bioengineering	1970	Active	Passed		128	18	63
2/6/2024	WH FOEGE BIOENG	N433C	Bioengineering	1965	Active	Passed		125	18	86
2/6/2024	WH FOEGE BIOENG	N557	Bioengineering	1951	Active	Passed		88	18	52
2/6/2024	WH FOEGE BIOENG	N451A	Bioengineering	1966	Active	Passed		105	18	52
2/6/2024	WH FOEGE BIOENG	N509C	Bioengineering	1960	Active	Passed		78	18	52
2/6/2024	WH FOEGE BIOENG	N509 B	Bioengineering	1961	Active	Failed		110	18	52
2/6/2024	WH FOEGE BIOENG	N523-C	Bioengineering	1959	Active	Failed		128	18	52
2/6/2024	WH FOEGE BIOENG	N509 B	Bioengineering	1963	Active	Passed		100	18	52
2/6/2024	WH FOEGE BIOENG	N509C	Bioengineering	1957	Active	Passed		127	18	52

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
2/6/2024	WH FOEGE BIOENG	N423C	Bioengineering	1964	Active	Failed		80	18	86
2/6/2024	WH FOEGE BIOENG	N509 B	Bioengineering	1962	Active	Passed		99	18	52
2/6/2024	WH FOEGE BIOENG	N451A	Bioengineering	1967	Active	Passed		124	18	52
2/6/2024	WH FOEGE BIOENG	N523C	Bioengineering	1958	Active	Failed		15	18	52
2/6/2024	WH FOEGE BIOENG	N551B	Bioengineering	1953	Active	Passed		99	18	52
2/6/2024	WH FOEGE BIOENG	N533C	Bioengineering	1955	Active	Passed		116	18	52
2/7/2024	WH FOEGE BIOENG	N323C	Bioengineering	1980	Active	Failed		111	18	52
2/7/2024	WH FOEGE BIOENG	N127N	Bioengineering	1991	Active	Passed		119	18	52
2/7/2024	WH FOEGE BIOENG	N323C	Bioengineering	1981	Active	Failed		88	18	52
2/7/2024	WH FOEGE BIOENG	N323C	Bioengineering	1976	Active	Failed		109	18	52
2/7/2024	WH FOEGE BIOENG	N323C	Bioengineering	1977	Active	Failed		107	18	52
2/7/2024	WH FOEGE BIOENG	N323D	Bioengineering	1982	Active	Passed		113	18	86
2/7/2024	WH FOEGE BIOENG	N323C	Bioengineering	1979	Active	Failed		122	18	52
2/7/2024	WH FOEGE BIOENG	N323D	Bioengineering	1983	Active	Passed		99	18	52
2/7/2024	WH FOEGE BIOENG	N409C	Bioengineering	1968	Active	Passed		110	18	50
2/7/2024	WH FOEGE BIOENG	N351A	Bioengineering	1971	Active	Passed		107	18	52
2/7/2024	WH FOEGE BIOENG	N333C	Bioengineering	1974	Active	Passed		101	18	52
2/7/2024	WH FOEGE BIOENG	N333C	Bioengineering	1975	Active	Passed		94	18	52
2/7/2024	WH FOEGE BIOENG	N333B	Bioengineering	1973	Active	Failed		110	18	50
2/7/2024	WH FOEGE BIOENG	N323C	Bioengineering	1978	Active	Failed		55	18	52
2/8/2024	WH FOEGE BIOENG	N215A	Bioengineering	1985	Active	Failed		109	18	52

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
2/8/2024	WH FOEGE BIOENG	N251 B	Bioengineering	1993	Active	Passed		121	18	52
2/8/2024	WH FOEGE BIOENG	N227C	Bioengineering	1988	Active	Passed		99	18	52
2/8/2024	WH FOEGE BIOENG	N209C	Bioengineering	1986	Active	Passed		116	18	52
2/8/2024	WH FOEGE BIOENG	N223C	Bioengineering	1987	Active	Failed		122	18	52
2/8/2024	WH FOEGE BIOENG	N261	Bioengineering	1990	Active	Failed		89	18	52
2/8/2024	WH FOEGE BIOENG	N251D	Bioengineering	1989	Active	Passed		106	18	52
2/20/2024	WH FOEGE BIOENG	N309B	Bioengineering	1984	Active	Failed		36	18	52
2/20/2024	WH FOEGE BIOENG	N551A	Bioengineering	1954	Active	Failed		93	18	52
4/30/2024	WH FOEGE BIOENG	N151	Bioengineering	1992	Active	Passed		120	18	52
5/3/2024	WH FOEGE BIOENG	N351C	Bioengineering	1972	Active	Passed		102	18	52
8/24/2023	WH FOEGE GENOME	S 031	Genome Sciences	2025	Active	Passed		112	18	62
2/21/2024	WH FOEGE GENOME	S 443	Genome Sciences	2047	Active	Passed		119	18	62
2/21/2024	WH FOEGE GENOME	S 403	Genome Sciences	2044	Active	Passed		105	18	62
2/21/2024	WH FOEGE GENOME	S 433	Genome Sciences	2046	Active	Failed		122	18	62
2/21/2024	WH FOEGE GENOME	S 410B	Genome Sciences	2049	Active	Passed		130	18	62
2/21/2024	WH FOEGE GENOME	S 420A	Genome Sciences	2048	Active	Passed		110	18	62
2/22/2024	WH FOEGE GENOME	S 041	Genome Sciences	2026	Active	Passed		118	18	62
2/22/2024	WH FOEGE GENOME	S 051	Genome Sciences	2027	Active	Passed		108	18	62
2/22/2024	WH FOEGE GENOME	S 021	Genome Sciences	2024	Active	Passed		82	18	62
2/22/2024	WH FOEGE GENOME	S 303	Genome Sciences	2038	Active	Passed		114	18	62
2/22/2024	WH FOEGE GENOME	S 310B	Genome Sciences	2043	Active	Passed		106	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
2/22/2024	WH FOEGE GENOME	S 313	Genome Sciences	2039	Active	Passed		114	18	62
2/22/2024	WH FOEGE GENOME	S 333	Genome Sciences	2040	Active	Passed		115	18	62
2/22/2024	WH FOEGE GENOME	S 343	Genome Sciences	2041	Active	Passed		112	18	62
2/22/2024	WH FOEGE GENOME	S 320A	Genome Sciences	2042	Active	Passed		112	18	62
2/23/2024	WH FOEGE GENOME	S 243	Genome Sciences	2035	Active	Passed		105	18	62
2/23/2024	WH FOEGE GENOME	S 203	Genome Sciences	2032	Active	Passed		109	18	62
2/23/2024	WH FOEGE GENOME	S 220A	Genome Sciences	2036	Active	Passed		120	18	62
2/23/2024	WH FOEGE GENOME	S 233	Genome Sciences	2034	Active	Passed		124	18	62
2/23/2024	WH FOEGE GENOME	S 210B	Genome Sciences	2037	Active	Passed		135	18	62
2/23/2024	WH FOEGE GENOME	S 143	Genome Sciences	2031	Active	Passed		123	18	62
2/23/2024	WH FOEGE GENOME	S 133	Genome Sciences	2030	Active	Passed		133	18	62
2/23/2024	WH FOEGE GENOME	S 113	Genome Sciences	2029	Active	Passed		104	18	62
2/23/2024	WH FOEGE GENOME	S 103	Genome Sciences	2028	Active	Passed		106	18	62
2/23/2024	WH FOEGE GENOME	S 213	Genome Sciences	2033	Active	Failed		109	18	62
9/11/2024	WH FOEGE GENOME	S 413	Genome Sciences	2045	Active	Passed		80	18	62
7/30/2024	WILCOX HALL	131	Materials Science and Engineering	1261	Active	Passed		117	18	60
7/30/2024	WILCOX HALL	141	Materials Science and Engineering	1262	Active	Passed		141	21	60
7/30/2024	WILCOX HALL	169	Civil and Environmental Engineering	117	Active	Passed		102	112	48
7/30/2024	WILCOX HALL	247	Bioengineering	1263	Active	Passed		134	18	60
7/30/2024	WILCOX HALL	249	Bioengineering	1324	Active	Passed		82	18	60
7/30/2024	WILCOX HALL	271	Civil and Environmental Engineering	128	Active	Passed		121	28	38

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
7/30/2024	WILCOX HALL	039	Materials Science and Engineering	1591	Active	Passed		87	29	64
7/30/2024	WILCOX HALL	139	Materials Science and Engineering	1735	Active	Passed		100	18	62
7/30/2024	WILCOX HALL	136	Materials Science and Engineering	114	Active	Passed		110	29	32
7/30/2024	WILCOX HALL	230A	Bioengineering	1264	Active	Passed		102	25	36
7/30/2024	WILCOX HALL	130	Materials Science and Engineering	1260	Active	Passed		91	18	60
7/30/2024	WILCOX HALL	136	Materials Science and Engineering	113	Active	Passed		104	29	32
10/2/2024	WILCOX HALL	239	Bioengineering	1265	Active	Passed		82	18	48
12/1/2023	WINKENWERDER HALL	212	Environmental and Forest Sciences	63	Active	Passed		93	18	44
3/7/2024	WINKENWERDER HALL	209	Environmental and Forest Sciences	60	Inactive	Failed		21	18	44
3/7/2024	WINKENWERDER HALL	106	Environmental and Forest Sciences	57	Active	Passed		117	23	44
3/7/2024	WINKENWERDER HALL	110	Environmental and Forest Sciences	59	Inactive	Failed		153	18	44
3/7/2024	WINKENWERDER HALL	112	Environmental and Forest Sciences	58	Inactive	Failed		154	18	44
3/7/2024	WINKENWERDER HALL	208	Environmental and Forest Sciences	61	Inactive	Failed		15	18	44
3/7/2024	WINKENWERDER HALL	213	Environmental and Forest Sciences	62	Active	Passed		142	24	44
3/7/2024	WINKENWERDER HALL	214	Environmental and Forest Sciences	65	Active	Passed		107	22	44
3/7/2024	WINKENWERDER HALL	215	Environmental and Forest Sciences	64	Active	Passed		133	26	44
3/7/2024	WINKENWERDER HALL	216	Environmental and Forest Sciences	67	Active	Failed		72	17	44
3/7/2024	WINKENWERDER HALL	217	Environmental and Forest Sciences	66	Inactive	Failed		24	18	44
3/7/2024	WINKENWERDER HALL	114	Environmental and Forest Sciences	56	Inactive	Failed		158	24	44